

**REQUEST FOR SEALED BIDS  
CITY OF JOHNSON CITY, TEXAS  
DEWATERING SLUDGE TRAILER**

**SUBMITTAL DEADLINE:** FRIDAY, OCTOBER 7, 2022 AT 3:00 P.M. C.S.T.  
CITY OF JOHNSON CITY CITY HALL  
303 E. PECAN DRIVE (Physical)  
P.O. BOX 369 (Mailing)  
JOHNSON CITY, TEXAS 78636

**BID OPENING:** FRIDAY, OCTOBER 7, 2022 AT 3:05 P.M. C.S.T.  
SAME LOCATION

**SCOPE OF WORK:**

The City of Johnson City is requesting sealed bids from qualified manufacturers and/or representatives for one (1) dewatering sludge trailer for the City’s Wastewater Treatment Plant.

**PROPOSED PROJECT SCHEDULE:**

1. Notice of Award to be sent by October 14, 2022.
2. Notice to Proceed to the manufacturer and/or representative from the City by October 21, 2022.

**PROJECT MINIMUM SPECIFICATIONS:**

Manufacturers and/or representatives shall bid the following minimum specifications, or equal. Manufacturers and/or representatives may substitute the named product for another product that meets or exceeds the identified product’s character, quality, and performance.

QTY	PART
1	Trailer mounted Sludge Mate®. Model SM-20-O-TM
	20 cu. yd. with hydraulic door.
	Pintle hitch.
	Open top mounted on a hydraulic tilting trailer. A-36 steel plate and structural members.
	Removable expanded metal filter support panels installed on the long sides and on each vertical face of the center panel.
	Each panel covered with poly 2000 filter media.
	Filter media and support panels fastened to internal structure with stainless steel studs, nuts, and washers.
	All panels to drain to a common cavity having two (2) 3” male hose cam connections each side at opposing ends located on the bottom rail.
	Hydraulically operated rear door.
	Sludge inlet to be 3” cam and groom female connector.
	Two (2) sight level indicators mounted on the front panel.
	12V DC battery powered hydraulic hoist w/ a control station on a 25’ lead.
	Payload dump capacity of 29,700 lbs.

	Standard highway lighting.
	15,000 lbs. dual tandem rocker slipper spring suspension axles w/ electric over hydraulic brakes.
	17.5” 16 ply radial tires.
	Single 18,000 lb. landing gear.
	Break-a-way switch.
	Exterior and interior surfaces and supports sandblasted to near white metal.
	Container and trailer surfaces coated with a two-part epoxy primer.
	Final topcoat to be polyurethane on all exterior surfaces.
	Interior topcoat to be epoxy mastic.
	All clamp bars and expanded metal panels to be hot dipped galvanized.

**SUBMITTALS EVALUATED AND RANKED AS FOLLOWS:**

Sealed bids evaluated and awarded to the lowest responsible bidder.

Please direct questions and inquiries regarding this Request for Sealed Bids to:

Rick Schroder  
City of Johnson City  
830.868.7111  
rschroder@johnsoncitytx.org

Addenda, if any, will be placed on the City of Johnson City main webpage, [www.johnsoncitytx.org](http://www.johnsoncitytx.org), under “Notices”.

