



303 E. Pecan Dr. Johnson City, TX 78636 | P.O. Box 369 Johnson City, TX 78636
Phone: 830.868.7111 | Fax: 830.868.7718 | Web: www.JohnsonCityTX.org

36

November 2023 Public Works Report

The Wastewater Treatment Plant discharged an average of 130,000 gallons per day.

The Brianna Circle lift station capacitors in the pump control panel and the cast-iron ears that hold the pump onto the bottom of the hole have been replaced.

We metered 4,000,000 gallons of water for the month. We are pumping an average of 4.5 hrs. a day.

The water leak on S. Ave F. is being addressed. Work will start on December 4th to install a valve on the water line. I'm still negotiating with 2 repair crews to find a cost-effective way to finish the job in a timely matter.

BJ Sultemeier