


[illegible]

	EXISTING WATER MAIN
	EXISTING FIRE HYDRANT
	PROPOSED WATER MAIN
	PROPOSED WATER LATERAL
	PROPOSED FIRE HYDRANT
	PROPOSED GATE VALVE
	PROPOSED BUTTERFLY VALVE
	PROPOSED BLOW-OFF VALVE
	PROPOSED AIR-RELEASE VALVE
	EXISTING SEWER LINE
	EXISTING SEWER MANHOLE
	PROPOSED SEWER LINE
	PROPOSED SEWER LATERAL
	PROPOSED SEWER MANHOLE
	PROPOSED CULVERT

MIN. SEPARATION REQUIREMENTS FOR UTILITIES:

1. SEWER & STORM DRAIN - 5' FROM OUTSIDE OF PIPE/STRUCTURE TO OUTSIDE OF PIPE/STRUCTURE.
2. WATER & SEWER - 10' FROM FROM OUTSIDE OF PIPE/STRUCTURE TO OUTSIDE OF PIPE/STRUCTURE.
3. WATER & STORM DRAIN - 4' FROM OUTSIDE OF PIPE/STRUCTURE TO OUTSIDE OF PIPE/STRUCTURE.
4. STORM & SEWER ARE REQUIRED TO BE BELOW WATER CROSSINGS BY 12" MIN.

* PROPERTY REQUIRES BACKWATER VALVE PER SPMUD STD. DWG. B.



C - 6

SW Corner of Rocklin Road and Barton Road
Loomis, California

SEPTEMBER 2, 2025
FOURTH SUBMITTAL

785 Orchard Drive, Suite #110
Folsom, CA 95630
Phone: (916) 608-0707
Fax: (916) 608-0701