



TOWN OF LOOMIS
3665 Taylor Road
P.O. Box 1330
Loomis, CA 95650
(916) 652-1840

12/5/2022

ATTN: All Prospective Bidders
PROJECT: Arcadia Avenue Storm Drain Repair Project
SUBJECT: **ADDENDUM NO. 1**

This Addendum is being issued to make the following changes or clarifications to the Contract Documents.

Material:

Concrete pipe shall be 18-inch, Class 5 with water proof gaskets and can be provided in 8-foot segments or 6-foot segments, depending upon material availability.

Testing:

Should testing need to be performed on the trench backfill or asphalt paving, it will be coordinated and paid for by the Town.

Acknowledgement:

Receipt of this Addendum must be acknowledged by bidders. Acknowledgement may be made by placing the number "1" in the Signature Pages, Addenda Section of the Proposal Forms **or** by signing and submitting this page with the bid proposal.

Name of Firm

Printed Name of Person Signing

Signature

Date

Prepared by: Merrill Buck
Town Engineer