



TOWN OF LOOMIS
3665 Taylor Road
P.O. Box 1330
Loomis, CA 95650
(916) 652-1840

2/28/2023

ATTN: All Prospective Bidders
PROJECT: Magnolia Street Storm Drain Replacement Project
SUBJECT: **ADDENDUM NO. 1**

This Addendum is being issued to make the following changes or clarifications to the Contract Documents.

General:

As a follow up to suggestions made at the pre-bid meeting, the Town has sent a letter to the property owner at 5906 Oak Street, to see if permission can be obtained to allow equipment to travel upon, and work from, this property. To allow more time for a response, the bid opening date is being extended by three weeks.

Bid Opening Date:

The new bid opening date and time will be on Thursday, March 23, 2023 at 10:00am.

Material:

The reference on Sheet 2 of the Plans, Notes 3 and 12, to the pipe being DR17 is incorrect. The pipe shall be as called out in the Specifications Section 16-02, which states that the pipe is to be smooth interior HDPE with angular exterior corrugations to the sizes noted on the plans.

Testing:

While not anticipated due to the use of CLSM backfill around the pipe, should testing need to be performed on the trench backfill, it will be coordinated and paid for by the Town.

Acknowledgement:

Receipt of this Addendum *must* be acknowledged by bidders. Acknowledgement shall be made by signing and submitting this page with the bid proposal.

Name of Firm

Printed Name of Person Signing

Signature

Date

Prepared by: Merrill Buck
Town Engineer