

ADDENDUM NO. 4

APRIL 11, 2018

CITY OF LUCAS

**PARKER ROAD WATER LINE PHASE 2 (Bid 013-18)
(FROM LEWIS LANE TO EAST OF SANTA FE TRAIL)**

This Addendum forms a part of the Contract Documents and Specifications. Acknowledge receipt of the Addendum in the space provided in the Bid Form and on the outer envelope of the Bid Proposal. Failure to acknowledge receipt of this Addendum may subject Bidder to disqualification.

PLANS

1. On Plan Sheet No. 2, in the General Notes, in Note No. 12, add the following:

“If the Contractor needs any additional space outside existing City easements and City right-of-way for construction activities, the Contractor shall be responsible for acquiring such space.”

2. On Plan Sheet No. 2, in the General Notes, in Note No. 28, change “New water service line shall be copper pipe with compression type fittings.” to “New water service line shall be 250 psi high density polyethylene pipe (HDPE).”