

Surface Water Treatment Technique: Non-Acute

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses and parasites that can cause systems such as nausea, diarrhea and associated headaches.

The City of Marlin TX0730002, failed to meet the minimum treatment technique requirements for the month of July 2020. Specifically, our water system had Failed to maintain microbial treatment.

The City of Marlin Water Plant PWS TX0730002 have taken the following action to prevent a recurrence of this violation. We corrected our procedures when maintenance occurs on the membranes. We conducted training on the procedures and it will be followed.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, school, and business). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Jennifer Trotter at 254-883-3371.

Posted / Delivered on: 7/15/2021
