

**PUBLIC NOTICE MANDATORY LANGUAGE CODING  
Tier 2 violations/ Non-Acute**

**Mandatory Language for Surface Water Treatment Technique Violation**

**SURFACE WATER TREATMENT TECHNIQUE: [NON-ACUTE]**

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. **These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.**

The **City of Marlin**, PWS ID **TX0730002**, failed to meet the minimum treatment technique requirements for the month of **April 14 2021**. Specifically, our water system had Failure to achieve at least 99% (2-log) removal of *Cryptosporidium*.

On April 14 2021, a Boil Water Notice was issued for the City of Marlin PWS0730002, a routine maintenance cleaning being done on SKID200 reviled multiple membrane filters needed to be pulled and re-pinned causing us to run low on water levels in our Mesquite tower (we never lost psi in town), the SKID did not pass the required weekly ITest. We put SKID200 into production to build our levels in town and to continue maintenance on the SKID for the next day. The Boil Water Notice was Rescinded on April 17,2021

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Jennifer Trotter at 254-883-3371.

Posted /Delivered on: 5/14/2021

---