

City of New Buffalo Sewer Study




February 19, 2019



Background

- Starting Fall 2017, several wet weather events caused elevated flows and surcharges, exceeding purchased capacity at the Wastewater Treatment Plant (WWTP)
- Additionally, the purchased capacity had been lowered in May 2017 causing the surcharge fees to be applied to a higher volume of flow while the base rate also increased each year
- Invoice totals from GRSD increased substantially
- Abonmarche engaged to investigate
- Purchased capacity increased back to 19.5 MG August 2018 (and 21.6 at end of 2018). Billing arrangement made between City & GRSD
- However, total flow volumes are still higher

City Used vs Purchased Capacity






Smoke Testing


- Performed on City's wastewater system in Sept/Oct to find sources of Inflow and Infiltration (I/I)
- 14 primary sources of I/I found such as:
 - Illegal connection from roof drain
 - Catch basin connects to wastewater pipe
 - Manhole structure joints have water weeping in
- 115 secondary sources such as:
 - Broken cleanout cap
 - Manhole rim with holes/gaps















Lift Station Flow Analysis


 Compared City's main lift station (LS 79) with recorded precipitation to show elevated flow volumes correlate to wet weather








Lift Station Flow Analysis


- Compared City's main lift station (LS 79) with recorded precipitation to show elevated flow volumes correlate to wet weather
- Reviewed each lift station's run times to isolate areas of town that have elevated wet weather flows













Areas to Investigate Further


Gravity Main Upstream LS 79



Lift Station Flow Analysis


- Compared City's main lift station (LS 79) with recorded precipitation to show elevated flow volumes correlate to wet weather
- Reviewed each lift station's run times to isolate areas of town that have elevated wet weather flows
- Comparing LS 79 calculated volumes to GRSD billed flow shows divergence starting in June 2018







Areas to Investigate Further

 Area between LS 79 and WWTP (both in the City and Township)



- Starting in June, 40% or more of total flow is coming from an area accounting for about 14% of the pipe network
- Average 340,000 gallons/day difference amounts to 8-14 million gallons/month
- Prior to June, this area contributed 0-23% of flow volume
- This area is composed of City and Township users with no direct mechanism to distinguish the two





Next Steps

- Address issues found during smoke testing
- Flow metering to target the two areas identified
 - Between LS 79 and WWTP
 - Upstream of LS 79
- Verify Schools connection

