



**PETALUMA FIRE PREVENTION BUREAU**  
 11 English Street, Petaluma, California 94952 Telephone:  
 (707) 778-4389 / Fax: (707) 776-3642  
[www.cityofpetaluma.net/firedept/prevention.html](http://www.cityofpetaluma.net/firedept/prevention.html)



ADDRESS: \_\_\_\_\_ DATE: \_\_\_\_\_

OWNER/APPLICANT: \_\_\_\_\_ PHONE/EMAIL: \_\_\_\_\_

PROJECT DESCRIPTION: \_\_\_\_\_ PERMIT #: B\_\_\_\_ - \_\_\_\_\_

ALL STRUCTURES:

AVAILABLE FIRE FLOW IS LESS THAN THE MINIMUM REQUIRED \_\_\_\_\_ GPM AT 20 PSI Yes  No

FIRE HYDRANT LOCATIONS EXCEED 400-FEET ALONG AN APPROVED PATH: Yes  No

FIRE DEPARTMENT ACCESS EXCEEDS 150-FEET ALONG AN APPROVED PATH: Yes  No

DETACHED ACCESSORY DWELLING UNITS:

TOTAL GROSS FLOOR AREA EXCEEDS 1,200 SQUARE FEET: Yes  No

PRIMARY RESIDENCE HAS AUTOMATIC FIRE SPRINKLERS: Yes  No

REMODELS/ADDITIONS/ATTACHED ACCESSORY DWELLING UNITS:

AUTOMATIC FIRE SPRINKLERS ARE EXISTING: Yes  No

TOTAL GROSS FLOOR AREA OF EXISTING STRUCTURE: \_\_\_\_\_ 50% = \_\_\_\_\_

PROPOSED TOTAL GROSS FLOOR AREA OF ADDITION: \_\_\_\_\_

PROPOSED TOTAL GROSS FLOOR AREA OF REMODEL: \_\_\_\_\_

GROSS FLOOR AREA WHERE CHANGES TO USABILITY OCCURS<sup>1</sup>: \_\_\_\_\_

GROSS FLOOR AREA OF CEILING FINISHES TO BE MODIFIED<sup>1</sup>: \_\_\_\_\_

TOTAL ADDITION + REMODEL AREAS EXCEEDS 50% OF EXISTING TOTAL GROSS FLOOR AREA: Yes  No

AUTOMATIC FIRE SPRINKLERS REQUIRED: Yes  No

<sup>1</sup> Record area of modification that is not otherwise already identified elsewhere in this section.

NOTES: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Signature: Fire Marshal or Representative

Print Name

Date