



# CITY OF PETALUMA

POST OFFICE BOX 61  
PETALUMA, CA 94953-0061

## ADDENDUM NO. 3.

### D Street Bridge Electric and System Upgrades City Project No. C16101933

February 7, 2020

Teresa Barrett  
Mayor

D'Lynda Fischer  
Mike Healy  
Gabe Kearney  
Dave King  
Kevin McDonnell  
Kathy Miller  
Councilmembers

This Addendum No. 3 modifies the Bidding Documents for the D Street Bridge Electrical and Systems Upgrade, City Project No. C16101933, and shall become part of the Contract Documents for this Project.

### I. SPECIAL PROVISIONS – QUESTION AND ANSWERS

**Q: On page 187 section T508-6.2.4 Programmable Logic Controller item 11. "Spare Parts: One each of every type card, power supply, or module required. Quantity of four (4) of each I/O module type used". Can you please clarify**

**A:** Section T508-6.2.4 shall be revised to state Spare Parts: One each of every type communication card, power supply and I/O module used.

**Q: On page 31 it calls for a dual hot standby CPU but on page 35 CPLX 69 with no exception. The CPLX69 is not a dual hot standby. Can you clarify?**

**A:** Section T508-6.2.4-B.1 shall be revised to state " The PLC system shall include a CP with a minimum user memory of 5 mega bites (MB), bus controller, power supplies, Input/Output modules and plug-in chassis." -NO HOT STAND BY TO BE REQUIRED ON THIS PROJECT. PLEASE NOTE THAT END OF SECTION 6.2.4 REQUIRES THE CONTRACTOR TO SUPPLY A PLC AS MANUFACTURED BY ALLEN BRADLEY MODEL COMPACTLOGIX 1769 – NO EXCEPTIONS.

**Q: Will there be an exception to the requirement of for previous experience with movable bridge projects?**

**A:** Yes, if the Contractor can assign a control system engineer for this project with the experience called for on T508-1.1.7, then we would be looking at this individuals experience to meet minimum requirements.

All other items of the documents shall remain unchanged. **A signed copy of this Addendum and the attached acknowledgement form shall be attached to the**

#### Public Works & Utilities

City Engineer  
11 English Street  
Petaluma, CA 94954  
Phone (707) 778-4303

Environmental Services  
Ellis Creek Water  
Recycling Facility  
3890 Cypress Drive  
Petaluma, CA 94954  
Phone (707) 776-3777  
Fax: (707) 656-4067

Parks & Facility  
Maintenance  
840 Hopper St. Ext.  
Petaluma, CA 94952  
Phone (707) 778-4303  
Fax (707) 206-6065

Transit Division  
555 N. McDowell Blvd.  
Petaluma, CA 94954  
Phone (707) 778-4421

Utilities & Field Operations  
202 N. McDowell Blvd.  
Petaluma, CA 94954  
Phone (707) 778-4546  
Fax (707) 206-6034

E-Mail: [publicworks@ci.petaluma.ca.us](mailto:publicworks@ci.petaluma.ca.us)

**bid proposal. Failure to do so may cause rejection of your bid as being non-responsive.**

A handwritten signature in black ink, appearing to read "Jeff Stutsman". The signature is fluid and cursive, with the first name "Jeff" and last name "Stutsman" clearly distinguishable.

---

Jeff Stutsman, P.E.,  
Traffic Engineer  
Public Works & Utilities Department

**ADDENDUM NO. 3**

**D Street Bridge Electric and System Upgrades  
City Project No. C16101933**

**February 7, 2020**

**ACKNOWLEDGEMENT**

Receipt of Addendum No. 1 is hereby acknowledged by \_\_\_\_\_  
(Contractor's Name)

on the \_\_\_\_\_ day of \_\_\_\_\_, 2020.

By: \_\_\_\_\_  
Signature

\_\_\_\_\_  
Title

\_\_\_\_\_  
Company