



CITY OF PETALUMA

POST OFFICE BOX 61
PETALUMA, CA 94953-0061

ADDENDUM NO. 1

Transit Center Parking & ADA Improvements City Project No. C65102009

February 26, 2020

This Addendum No. 1 modifies the Bidding Documents for the Transit Center Parking & ADA Improvements project, City Project No. 65102009, and shall become part of the Contract Documents for this Project.

QUESTION AND ANSWER

Q: Will the City require public access to the property through the construction site?

A: No. The contractor shall submit a Traffic Control Plan (TCP) which indicates how pedestrian traffic will be routed around the jobsite to the front gate of the Transit Center along McDowell Blvd. The TCP shall contain details regarding all appropriate delineation, barricades and signage required.

Q: Will temporary fencing be required?

A: Fencing will be required to limit public access in the construction zone. In addition, temporary fencing will be required for the demolition of the existing fence. Note: temporary fencing must maintain the same level of security as the current fence.

Q: What is to be done with the irrigation system within the project excavation area?

A: Irrigation lines within the project area shall be removed and disposed of by the Contractor. The main irrigation line (which is anticipated to run from N. McDowell along Transit Way) shall be capped to the northwest side of the proposed concrete stairs. The Contractor shall expose this main line closest to the project area and discuss with the Engineer prior to cutting and capping.

Q: What is the plan for excess spoils produced during the project excavation?

A: The project Engineer estimates that all excavated soil can be re-used on site by regrading the site. Excess soil can be disposed of at the Petaluma Airport. Access, and disposal location shall be coordinated with the City's project Engineer.

Q: Are there any Disadvantaged Business Enterprise (DBE) requirements?

A: DBE is encouraged but not required.

Q: What are the Transit Center main gate (along McDowell) hours?

A: 7 AM to 6 PM

Comments: All utility boxes embedded in the sidewalk must be slip resistant.

Teresa Barrett
Mayor

D'Lynda Fischer
Mike Healy
Gabe Kearney
Dave King
Kevin McDonnell
Kathy Miller
Councilmembers

Public Works & Utilities

City Engineer
11 English Street
Petaluma, CA 94952
Phone (707) 778-4303

Environmental Services
Ellis Creek Water
Recycling Facility
3890 Cypress Drive
Petaluma, CA 94954
Phone (707) 776-3777
Fax: (707) 656-4067


*Parks & Facility
Maintenance*
840 Hopper St. Ext.
Petaluma, CA 94952
Phone (707) 778-4303
Fax (707) 206-6065

Transit Division
555 N. McDowell Blvd.
Petaluma, CA 94954
Phone (707) 778-4421

Utilities & Field Operations
202 N. McDowell Blvd.
Petaluma, CA 94954
Phone (707) 778-4546
Fax (707) 206-6034

E-Mail: publicworks@cityofpetaluma.org

All other items of the documents shall remain unchanged. **A signed copy of this Addendum and the attached acknowledgement form shall be attached to the bid proposal. Failure to do so may cause rejection of your bid as being non-responsive.**



Jonathan Sanglerat
Assistant Engineer II
Public Works & Utilities Department

ADDENDUM NO. 1

**Transit Center Parking & ADA Improvements
City Project No. C65102009**

February 26, 2020

ACKNOWLEDGEMENT

Receipt of Addendum No. 1 is hereby acknowledged by _____
(Contractor's Name)

on the _____ day of _____, 2020.

By: _____

Signature

Title

Company