



CITY OF PETALUMA

POST OFFICE BOX 61
PETALUMA, CA 94953-0061

ADDENDUM NO. 2

Transit Center Parking & ADA Improvements City Project No. C65102009

February 27, 2020

This Addendum No. 2 modifies the Bidding Documents for the Transit Center Parking & ADA Improvements project, City Project No. 65102009, and shall become part of the Contract Documents for this Project.

QUESTION AND ANSWER

Q: The specified (Ameristar) permanent fencing system offers a 2-rail and a 3-rail option, which option is required for this project?

A: For bidding purposes please assume a 2-rail option will be required. Awarded contractor shall submit proposed fencing system to the City for final approval.

Q: What are the hardware requirements for the project's permanent fencing - specifically regarding locking mechanisms and hinges for the pedestrian gate?


A: As shown on the drawings for a typical pedestrian gate (Aegis II – Invincible option) on the Ameristar website, the project fencing hardware shall include a pad-lockable latch with heavy duty hinges.

Q: What handrail pipe dimensions and pipe-wall thicknesses should be assumed?

A: Handrails are required to meet all ADA and UBC requirements to the most stringent application. See project plans (Sheet D-2, page 9 of 11) and specifications. Awarded contractor shall submit proposed handrail system to the City for final approval.

Comments: As outlined in the specifications the project's pedestrian gate is intended to remain open (secured by a latch) during normal business hours. In addition, the gate shall open inwards, towards the Transit Center.

All other items of the documents shall remain unchanged. **A signed copy of this Addendum and the attached acknowledgement form shall be attached to the bid proposal. Failure to do so may cause rejection of your bid as being non-responsive.**


Jonathan Sanglerat
Assistant Engineer II
Public Works & Utilities Department

Teresa Barrett
Mayor

D'Lynda Fischer
Mike Healy
Gabe Kearney
Dave King
Kevin McDonnell
Kathy Miller
Councilmembers

Public Works & Utilities

City Engineer
11 English Street
Petaluma, CA 94952
Phone (707) 778-4303

Environmental Services

Ellis Creek Water
Recycling Facility
3890 Cypress Drive
Petaluma, CA 94954
Phone (707) 776-3777
Fax: (707) 656-4067

Parks & Facility Maintenance

840 Hopper St. Ext.
Petaluma, CA 94952
Phone (707) 778-4303
Fax (707) 206-6065

Transit Division

555 N. McDowell Blvd.
Petaluma, CA 94954
Phone (707) 778-4421

Utilities & Field Operations

202 N. McDowell Blvd.
Petaluma, CA 94954
Phone (707) 778-4546
Fax (707) 206-6034

E-Mail: publicworks@
cityofpetaluma.org

ADDENDUM NO. 2

**Transit Center Parking & ADA Improvements
City Project No. C65102009**

February 27, 2020

ACKNOWLEDGEMENT

Receipt of Addendum No. 2 is hereby acknowledged by _____
(Contractor's Name)

on the _____ day of _____, 2020.

By: _____
Signature

Title

Company