

Teresa Barrett Mayor

D'Lynda Fischer Mike Healy Gabe Kearney Dave King Kevin McDonnell Kathy Miller Councilmembers

#### Public Works & Utilities

*City Engineer* 11 English Street Petaluma, CA 94952 Phone (707) 778-4303

**Environmental Services** 

Ellis Creek Water Recycling Facility 3890 Cypress Drive Petaluma, CA 94954 Phone (707) 776-3777 Fax: (707) 656-4067

Parks & Facility Maintenance 840 Hopper St. Ext. Petaluma, CA 94952 Phone (707) 778-4303 Fax (707) 206-6065

*Transit Division* 555 N. McDowell Blvd. Petaluma, CA 94954 Phone (707) 778-4421

Utilities & Field Operations 202 N. McDowell Blvd. Petaluma, CA 94954 Phone (707) 778-4546 Fax (707) 206-6034

> E-Mail: publicworks@ cityofpetaluma.org

# CITY OF PETALUMA

POST OFFICE BOX 61 PETALUMA, CA 94953-0061

#### ADDENDUM NO. 5

#### Airport Monument Sign City Project No. C61501907

#### July 29, 2020

This Addendum No. 5 modifies the Bidding Documents for the Airport Monument Sign project, City Project No. C61501907, and shall become part of the Contract Documents for this Project.

### **QUESTION AND ANSWER**

**Q:** In Addendum No. 3, the answer to the first question included the statement, "Please note that all excavated material can be stored at the Petaluma Airport, and thus will not require off-hauling." Does this statement also apply to the removed components of the existing monument sign, e.g., timbers, metal, etc.?

A: The City will direct the contractor to dispose of rocks and soil at the Airport. The contractor is required to dispose of all other materials including, but not limited to, concrete, wood, metal, and debris off site.

**Q:** The tops of the concrete footings for the existing sign are just above grade. What is the extent of demolition required for these existing footings?

A: The existing concrete footings shall be removed to at least one (1) foot below grade and covered with compacted soil.

**Q:** With regard to the rocks piled around the base of the existing monument sign, does the scope of work require their complete removal and relocation to the previously-mentioned designated site on the airport grounds, or are those rocks to be left on site at or near their current location, or are they to be re-used at the new monument sign location? **A:** See response to the first question above.

All other items of the documents shall remain unchanged. A signed copy of this Addendum and the attached acknowledgement form shall be attached to the bid proposal. Failure to do so may cause rejection of your bid as being non-responsive.

Then Going het

Jonathan Sanglerat Assistant Engineer II Public Works & Utilities Department

#### **ADDENDUM NO. 5**

## Airport Monument Sign City Project No. C61501907

### July 29, 2020

#### **ACKNOWLEDGEMENT**

Receipt of Addendum No. 5 is hereby acknowledged by \_\_\_\_\_\_(Contractor's Name)

on the \_\_\_\_\_\_ day of \_\_\_\_\_\_, 2020.

By: \_\_\_\_

Signature

Title

Company