



# CITY OF PETALUMA

POST OFFICE BOX 61  
PETALUMA, CA 94953-0061

## ADDENDUM NO. 2

### North McDowell Boulevard Complete Streets Project City Project Number C16102147

August 8, 2022

This Addendum No. 2 modifies the Bidding Documents for the North McDowell Boulevard Complete Streets Project, City Project Number C16102147. This Addendum shall become part of the Contract and all provisions of the Contract shall apply thereto. Bidders shall acknowledge all Addendums in the Bid Schedule.

### QUESTIONS AND ANSWERS

**Q:** Pavement Recycling is telling us that the 1" CCPRAC leveling course can't be constructed as shown because the mix they will be providing has a 1" minus gradation and the leveling course will be difficult to put down and keep from unraveling. Can the City change the location of the Glasgrid within the pavement section so we can avoid the thin lift?

**A:** Thickness of leveling course below Glasgrid can be increased with CCPR section above Glasgrid being decreased. This modification will be reflected in the conformed construction set. No change in quantities needed for this adjustment.

**Q:** TS 50C.1 says that we are to place 3 PCMS for the project. TS 3.8 says to place 4 PCMS for the project. Does the City want 3 or 4 PCMS for the duration of the project?

**A:** Please plan on providing three (3) message signs for the project.

**Q:** In the Notice Inviting Bid Changes under Opening of Bids it indicates the bids will be ranked based by the Base Bid dollar amount. But, under Bid Schedule it indicates Bid Award will be based on Base Bid plus Additive Alternative 1 Signal Interconnect. Please confirm the award will be Base Bid plus Alt 1.

**A:** Award will be Base Bid plus Alt 1

**Q:** Do you plan on having a Zoom meeting so the contractors can witness the bid opening and ask questions?

**A:** No, not at this time.

**Teresa Barrett**  
Mayor

**Brian Barnacle**  
**D'Lynda Fischer**  
**Mike Healy**  
**Dave King**  
**Kevin McDonnell**  
**Dennis Pocekay**  
Councilmembers

#### **Public Works & Utilities**

**City Engineer**  
11 English Street  
Petaluma, CA 94952  
Phone (707) 778-4303

#### **Environmental Services**

Ellis Creek Water  
Recycling Facility  
3890 Cypress Drive  
Petaluma, CA 94954  
Phone: (707) 776-3777  
Fax: (707) 656-4067

#### **Parks & Facility Maintenance**

840 Hopper St. Ext.  
Petaluma, CA 94952  
Phone (707) 778-4303  
Fax (707) 206-6065

#### **Transit Division**

555 N. McDowell Blvd.  
Petaluma, CA 94954  
Phone (707) 778-4421

#### **Utilities & Field Operations**

202 N. McDowell Blvd.  
Petaluma, CA 94954  
Phone (707) 778-4546  
Fax (707) 206-6034

E-Mail: publicworks@  
cityofpetaluma.org

**Summary of Changes:** Pavement structure section can be adjusted; 3 message signs are necessary; award based on Base Bid plus Alternative 1; and, there is no Zoom meeting for opening. All other items of the bid documents shall remain unchanged.

City of Petaluma,



---

Ken Eichstaedt, P.E, T.E.  
Senior Traffic Engineer  
Public Works & Utilities Department

**A signed copy of this Addendum and the attached acknowledgment form shall be attached to the bid proposal. Failure to do so may cause rejection of your bid as being non-responsive.**

**ADDENDUM NO. 2**

**North McDowell Boulevard Complete Streets Project  
City Project Number C16102147**

**August 8, 2022**

**ACKNOWLEDGEMENT**

Receipt of Addendum No. 2 is hereby acknowledged by \_\_\_\_\_  
(Contractor's Name)  
on the \_\_\_\_\_ day of \_\_\_\_\_, 2022.

By: \_\_\_\_\_  
Signature

\_\_\_\_\_  
Title

\_\_\_\_\_  
Company