

ADDENDUM NO. 1
POTTERY AVE NON-MOTORIZED IMPROVEMENTS PROJECT

Date Published: January 12 & 19, 2024
Date of Addendum #1: February 1, 2024
Date of Bid Opening: February 8, 2024

Notice to all Plan Holders:

The City has received questions regarding the bid package. Questions and answers are as follows:

Question No. 1

- Will JSF Technologies RRFB be allowed as an approved equal in lieu of the specified RRFB on this project?
 - The JSF Technologies RRFB solar panel is not equivalent to the Carmanah RRFB solar panel. Additionally, the JSF product appears to lack the simple on-board user interface and adjustable settings of the Carmanah product. The warranty for the JSF product also does not match the Carmanah warranty. For these reasons, use of the JSF Technologies RRFB in this project as an approved equal will not be accepted.

Question No. 2

- Does this project have any Buy America or AIS requirements?
 - This project does not have any Buy America or AIS requirements as there is no federal funding nor any funding from Clean Water State Revolving Fund and Drinking Water State Revolving Fund as a part of this project.

Question No. 3

- Do the hydrants for this project need to be Clow Medallion?
 - Per the specifications, hydrants can be either Clow Medallion or M&H 129S.

End of Addendum No. 1