

ADDENDUM NO. 2
POTTERY AVE NON-MOTORIZED IMPROVEMENTS PROJECT

Date Published: January 12 & 19, 2024
Date of Addendum #2: February 6, 2024
Date of Bid Opening: February 8, 2024

Notice to all Plan Holders:

The City has received questions regarding the bid package. Questions and answers are as follows:

Question No. 1

- Is the force main sanitary sewer to remain live while we are digging adjacent to it with the new force main?
 - Yes, the existing 6" sanitary sewer force main will remain live while the new 10" HDPE force main is installed. The existing 6" force main will remain live and operational after installation of the new 10" force main.

End of Addendum No. 2