

# **Appendix G- Sidewalk Evaluation by Precision Concrete**



# Third Street Corridor Sidewalk Assessment



03-25-2018

BKF Engineers San Rafael 3rd 3-25-18 AO

**Total Cost= \$9,845.00**

**Total Remove and Replace= 6211.5**







No.	Sidewalk off-set Max height (8ths)	Location	Cost	Notes	R&R SQ FT	Image1	Image2
41	2	926, 3rd St	\$5.00	926 3rd st crack in citysidewalk at tree			
42	4	926, 3rd St	\$40.00	926 3rd st citysidewalk at tree past No Parking sign parallel cut			
43	4	926, 3rd St	\$25.00	926 3rd st citysidewalk at tree at handicap parking X cut			
44	3	926, 3rd St	\$18.75	926 3rd st citysidewalk at tree at handicap parking X cut			
45	0	926, 3rd St		R&R 926 3rd st citysidewalk at tree at handicap parking. Citysidewalk and curb lifted by roots	200		








46	0	926, 3rd St		R&R 926 3rd st citysidewalk at driveway at sewer cap. Slab is cracked and piece loose	200		
47	0	926, 3rd St		ATTN 926 3rd st Pacific Bell box in citysidewalk needs replacement	8		
48	5	926, 3rd St	\$137.50	926 3rd st citysidewalk at garage driveway parallel cut			
49	0	926, 3rd St		R&R 926 3rd st citysidewalk at driveway. Citysidewalk is gapped cracked and broken	350		
50	0	1003, 3rd St		R&R 926 3rd st citysidewalk at light pole 523. Citysidewalk is gapped cracked and broken at Pac Bell box (needs replacement)	300		
51	4	1030, 3rd St	\$25.00	1030 3rd st citysidewalk at tree at asphalt patch L cut			



### Third Street Corridor Sidewalk Assessment

03-25-2018







52	5	1030, 3rd St	\$12.50	1030 3rd st citysidewalk at tree at asphalt patch L cut		
53	8	1030, 3rd St	\$140.00	1030 3rd st crack in citysidewalk at tree at asphalt patch L cut		
54	12	1030, 3rd St	\$180.00	1030 3rd st citysidewalk at tree at asphalt patch L cut		
55	12	1033, 3rd St	\$15.00	1030 3rd st citysidewalk at tree at asphalt patch L cut		
56	12	1033, 3rd St	\$180.00	1030 3rd st crack in citysidewalk at tree at asphalt patch		
57	6	1030, 3rd St	\$110.00	1030 3rd st citysidewalk at tree at asphalt patch		









58	0	1033, 3rd St		R&R 1030 3rd st citysidewalk at tree at asphalt patch at corner. Roots lifted and cracked slabs	200		
59	0	1030, 3rd St		ATTN 1030 3rd st at A street No Truncated Domes at ped-ramp at corner			
60	0	1100-1122, 3rd St		ATTN 3rd st at 901 A street No Truncated Domes at ped-ramp at corner			
61	3	1100, 3rd St	\$15.00	3rd st at 901 A st citysidewalk at ramp L cut			
62	3	1100-1122, 3rd St	\$11.25	3rd st at 901 A st citysidewalk at ramp L cut			
63	0	1100, 3rd St		ATTN 1100 3rd st Pacific Bell Box at citysidewalk needs replacement	24		



# Third Street Corridor Sidewalk Assessment

03-25-2018







64	3	1100, 3rd St	\$37.50	1100 3rd st citysidewalk at Pacific Bell Box	
65	6	1100, 3rd St	\$37.50	1100 3rd st citysidewalk at Street Lighting box L cut	
66	6	1101, 3rd St	\$22.50	1100 3rd st citysidewalk at Street Lighting box L cut L cut	
67	3	1101, 3rd St	\$37.50	1100 3rd st citysidewalk at Street Lighting box L cut	
68	3	1100, 3rd St	\$45.00	1100 3rd st citysidewalk at Street Lighting box at light pole 200 parallel cut	
69	3	1115, 3rd St	\$41.25	1100 3rd st citysidewalk past light pole 200	

70	0	1148, 3rd St		R&R 1100 3rd st citysidewalk past light pole 200. Citysidewalk is lifted	32		
71	5	1148, 3rd St	\$140.00	1100 3rd st citysidewalk at parking lt entrance			
72	4	1117, 3rd St	\$120.00	1100 3rd st citysidewalk at parking lt entrance			
73	7	1148, 3rd St	\$180.00	1100 3rd st citysidewalk at asphalt patch at tree past driveway			
74	0	1178-1198, 3rd St		R&R 1100 3rd st citysidewalk at asphalt patch at tree past driveway. Slab is lifted by roots	64		
75	3	1178-1198, 3rd St	\$37.50	1100 3rd st citysidewalk at tree before corner			


















# Third Street Corridor Sidewalk Assessment

03-25-2018

76	2	1178-1198, 3rd St	\$80.00	1100 3rd st citysidewalk at tree before corner		
77	0	1178-1198, 3rd St		ATTN 1100 3rd st at B st No Truncated Domes at ped-ramp at corner		
78	4	1228-1252, 3rd St	\$80.00	1216 3rd st citysidewalk at tree by MC Nottingham box		
79	5	1216, 3rd St	\$166.25	1216 3rd st citysidewalk at tree past MC Nottingham box		
80	4	1216, 3rd St	\$60.00	1216 3rd st citysidewalk at tree at crack		
81	4	1216, 3rd St	\$60.00	1216 3rd st citysidewalk at tree parallel cut L cut		



82	3	1216, 3rd St	\$30.00	1216 3rd st citysidewalk at tree L cut		
83	0	901, C St		ATTN 3rd st at 901 C st No Truncated Domes at ped-ramp at corner		
84	5	1300-1320, 3rd St	\$37.50	3rd st at 901 C st citysidewalk past corner L cut		
85	6	1323-1375, 3rd St	\$315.00	3rd st at 901 C st citysidewalk past corner parallel cut L cut		
86	3	1301-1321, 3rd St	\$7.50	3rd st at 901 C st citysidewalk past corner L cut		
87	8	1301-1321, 3rd St	\$50.00	3rd st at 901 C st citysidewalk past corner parallel cut L cut		

88	3	1323-1375, 3rd St	\$11.25	3rd st at 901 C st citysidewalk past corner L cut			
89	6	1306, 3rd St	\$45.00	1306 3rd st citysidewalk at crack			
90	5	1323-1375, 3rd St	\$37.50	1306 3rd st citysidewalk at crack at curb			
91	0	911, C St		R&R 1308 3rd st citysidewalk at driveway. Holes in citysidewalk at cracks and pieces missing from curb	260		
92	0	1312, 3rd St		R&R 1308 3rd st citysidewalk past driveway. Holes in citysidewalk at cracks at Utility boxes			
93	0	910, D St		R&R 1308 3rd st citysidewalk past driveway. citysidewalk has pieces loose	216		



### Third Street Corridor Sidewalk Assessment

03-25-2018

94	0	910, D St		R&R 3rd st at 910 D st citysidewalk at driveway. citysidewalk is cracked and gapped	200		
95	9	1322-1374, 3rd St	\$45.00	3rd st at 910 D st citysidewalk at crack at end of driveway L cut			
96	10	1312, 3rd St	\$125.00	3rd st at 910 D st citysidewalk at crack at end of driveway L cut			
97	0	910, D St		ATTN 3rd st at 910 D st Hole in citysidewalk past driveway Needs fill			
98	5	910, D St	\$56.25	3rd st at 910 D st citysidewalk past driveway parallel cut			
99	8	1322-1374, 3rd St	\$150.00	3rd st at 910 D st citysidewalk at asphalt patch past driveway L cut			



# Third Street Corridor Sidewalk Assessment







03-25-2018











100	7	1322-1374, 3rd St	\$43.75	3rd st at 910 D st citysidewalk at asphalt patch past driveway parallel cut L cut			
101	0	1322-1374, 3rd St		R&R 3rd st at 910 D st citysidewalk at tree past parking lot	200		
102	3	1376-1398, 3rd St	\$11.25	3rd st at 910 D st citysidewalk at tree past parking lot parallel cut L cut			
103	3	910, D St	\$11.25	3rd st at 910 D st citysidewalk at tree past parking lot L cut X cut			
104	10	910, D St	\$62.50	3rd st at 910 D st citysidewalk at tree past parking lot X cut			
105	4	1376-1398, 3rd St	\$70.00	3rd st at 910 D st citysidewalk at sewer by corner			









# Third Street Corridor Sidewalk Assessment

03-25-2018

106	0	1376-1398, 3rd St		ATTN 3rd st at 910 D st No Truncated Domes at ped-ramp at corner		
107	0	905, D St		ATTN 3rd st at 909 D st No Truncated Domes at ped-ramp at corner		
108	4	1400-1422, 3rd St	\$10.00	3rd st at 910 D st Citysidewalk at fire hydrant L cut		
109	2	1400-1422, 3rd St	\$60.00	3rd st at 910 D st Citysidewalk at fire hydrant parallel cut L cut		
110	3	1400-1422, 3rd St	\$37.50	3rd st at 910 D st Citysidewalk past fire hydrant L cut		
111	6	1424-1456, 3rd St	\$52.50	3rd st at 910 D st Citysidewalk at tree		







112	6	905, D St	\$45.00	3rd st at 910 D st Citysidewalk at tree at asphalt patch L cut			
113	10	1424-1456, 3rd St	\$200.00	3rd st at 910 D st Citysidewalk at tree at asphalt patch L cut			
114	0	1410, 3rd St		R&R 1410 3rd st Citysidewalk at tree at driveway. Citysidewalk is cracked and lifted by roots. Sunken at PG&E box	350		
115	0	1410, 3rd St		R&R 1410 3rd st Citysidewalk at driveway. Citysidewalk is cracked and sunken	45		
116	0	1414, 3rd St		R&R 1414 3rd st Citysidewalk at driveway. Citysidewalk is cracked and lifted by roots	200		
117	0	908, E St		R&R 3rd st at 908 E st Citysidewalk at driveway. Citysidewalk is cracked and lifted by roots	400		

118	6	1478-1498, 3rd St	\$22.50	3rd st at 908 E st crack in citysidewalk by corner L cut		
119	3	1478-1498, 3rd St	\$15.00	3rd st at 908 E st crack in citysidewalk by corner L cut		
120	8	1478-1498, 3rd St	\$20.00	3rd st at 908 E st citysidewalk at tree by corner L cut		
121	6	1478-1498, 3rd St	\$37.50	3rd st at 908 E st citysidewalk at tree by corner L cut x cut		
122	5	1478-1498, 3rd St	\$25.00	3rd st at 908 E st citysidewalk at tree by corner x cut L cut		
123	0	1478-1498, 3rd St		R&R 3rd st at 908 E st citysidewalk past tree at corner. Slab is broken		25












# Third Street Corridor Sidewalk Assessment







03-25-2018







124	5	1478-1498, 3rd St	\$90.00	3rd st at 908 E st citysidewalk at corner.	
125	0	1478-1498, 3rd St		ATTN 3rd st at 908 E st No Truncated Domes at ped-ramp at corner	
126	0	901, E St		ATTN 3rd st at 901 E st No Truncated Domes at ped-ramp at corner	
127	0	1479-1499, 3rd St		ATTN 3rd st at 901 E st No Truncated Domes at ped-ramp at corner	
128	3	901, E St	\$15.00	3rd st at 901 E st Citysidewalk past corner X cut	
129	7	807, E St	\$78.75	3rd st at 901 E st Citysidewalk past corner X cut	
















130	0	1500-1518, 3rd St		R&R 3rd st at 901 E st Citysidewalk past corner. Citysidewalk is cracked and lifted	168	
131	3	1520-1564, 3rd St	\$60.00	3rd st at 901 E st Citysidewalk past street lighting box		
132	12	1520-1564, 3rd St	\$240.00	3rd st at 901 E st Citysidewalk past street lighting box at asphalt patch		
133	5	901, E St	\$68.75	3rd st at 901 E st Citysidewalk past street lighting box at asphalt patch		
134	4	220, Shaver St U 100	\$75.00	3rd st at 220 Shaver st Citysidewalk at back fence		
135	0	104, Shaver St		R&R 3rd st at 104 Shaver st Citysidewalk at back fence at driveway. Piece is broken	120	

136	0	1566-1582, 3rd St		ATTN 3rd st at 104 Shaver st No Truncated Domes at ped-ramp at corner			
137	0	103, Shaver St		ATTN 3rd st at 103 Shaver st No Truncated Domes at ped-ramp at corner			
138	0	1532, 3rd St		R&R 1532 3rd st citysidewalk at driveway. Slab is sunken and cracked	125		
139	0	1540, 3rd St		R&R 1540 3rd st citysidewalk at driveway. Slab is sunken and cracked	50		
140	5	1544, 3rd St	\$31.25	1544 3rd st citysidewalk at at walkway old grind X cut			
141	5	18-98, Hayes St	\$31.25	1544 3rd st citysidewalk at at walkway old grind X cut			

142	0	1602-1624, 2nd St		R&R 1600 3rd st citysidewalk past Hayes corner citysidewalk is lifted and curb parts missing	80		
143	5	1606, 3rd St	\$56.25	1606 3rd st citysidewalk at garage walkway entrance old grind			
144	0	1618, 2nd St		R&R 1618 3rd st citysidewalk at driveway. Citysidewalk is cracked	60		
145	0	1654, 2nd St		ATTN 1654 3rd st hole in citysidewalk by sewer needs fill	1		
146	0	1660, 2nd St		ATTN 1660 3rd st hole in citysidewalk past sewer needs fill	25		
147	0	55, Shaver St		ATTN 3rd st at 55 Shaver St No Truncated Domes at ped-ramp at corner			

148	0	50-98, Shaver St		ATTN 3rd st at 1524 2nd St at Haver st No Truncated Domes at ped-ramp at corner			
149	0	1567-1583, 3rd St		R&R 3rd st at 1524 2nd St citysidewalk past driveway. Slab is cracked and gapped	320		
150	5	1521-1565, 3rd St	\$62.50	3rd st at 1524 2nd St citysidewalk at tree past driveway			
151	4	1521-1565, 3rd St	\$150.00	3rd st at 1524 2nd St citysidewalk past driveway			
152	11	1515, 3rd St	\$123.75	1515 3rd st citysidewalk past driveway			
153	4	1515, 3rd St	\$35.00	1515 3rd st crack in citysidewalk at tree past driveway			

154	0	1515, 3rd St		R&R 1515 3rd st citysidewalk at light pole 2800. Slab is sunken	64		
155	2	1515, 3rd St	\$22.50	1515 3rd st citysidewalk at parking lot			
156	0	1515, 3rd St		ATTN 1515 3rd st at E st No Truncated Domes at ped-ramp at corner			
157	0	1479-1499, 3rd St		ATTN 3rd st at 824 E st No Truncated Domes at ped-ramp at corner			
158	4	1479-1499, 3rd St	\$10.00	3rd st at 824 E st citysidewalk past corner			
159	3	1459-1477, 3rd St	\$26.25	3rd st at 824 E st citysidewalk at PG&E box			

160	5	1405, 3rd St	\$93.75	1405 3rd st citysidewalk at tree parallel cut L cut	
161	5	1405, 3rd St	\$31.25	1405 3rd st citysidewalk at tree L cut	
162	8	1405, 3rd St	\$40.00	1405 3rd st crack in citysidewalk at tree	
163	4	1405, 3rd St	\$40.00	1405 3rd st citysidewalk at tree at crack	
164	4	1405, 3rd St	\$35.00	1405 3rd st citysidewalk at tree by Door A	
165	3	1401-1423, 3rd St	\$11.25	1405 3rd st citysidewalk at tree by Door A L cut	



# Third Street Corridor Sidewalk Assessment







03-25-2018

166	3	1401-1423, 3rd St	\$22.50	1405 3rd st citysidewalk at tree by Door A parallel cut L cut	
167	2	1401-1423, 3rd St	\$7.50	1405 3rd st crack in citysidewalk at tree by Door A	
168	4	1401-1423, 3rd St	\$55.00	1405 3rd st citysidewalk at sewer L cut	
169	3	1401-1423, 3rd St	\$7.50	1405 3rd st citysidewalk at sewer L cut	
170	6	1401-1423, 3rd St	\$90.00	1405 3rd st citysidewalk by sewer parallel cut L cut	
171	7	1401-1423, 3rd St	\$43.75	1405 3rd st crack in citysidewalk by sewer L cut	



# Third Street Corridor Sidewalk Assessment

03-25-2018



172	8	1401-1423, 3rd St	\$50.00	1405 3rd st citysidewalk at crack by sewer L cut	
173	0	1401-1423, 3rd St		ATTN 1405 3rd st at D st No Truncated Domes at ped-ramp at corner	
174	0	1325, 3rd St		ATTN 1325 3rd st at D st No Truncated Domes at ped-ramp at corner	
175	5	1325, 3rd St	\$43.75	1325 3rd st csw at entrance	
176	4	1321, 3rd St	\$25.00	1321 3rd st citysidewalk by entrance X cut	
177	4	1321, 3rd St	\$25.00	1321 3rd st citysidewalk by entrance X cut	

























# Third Street Corridor Sidewalk Assessment

03-25-2018

178	8	1321, 3rd St	\$80.00	1321 3rd st citysidewalk at driveway			
179	8	1321, 3rd St	\$137.50	1321 3rd st citysidewalk at end of property			
180	0	855, C St		R&R 3rd st at 855 C st tree planter strip at citysidewalk needs replacement	16		
181	6	1323-1375, 3rd St	\$67.50	3rd st at 855 C st citysidewalk by tree L cut			
182	5	1323-1375, 3rd St	\$62.50	3rd st at 855 C st citysidewalk by tree L cut X cut			
183	3	1323-1375, 3rd St	\$22.50	3rd st at 855 C st citysidewalk by tree X cut L cut			

184	4	1323-1375, 3rd St	\$50.00	3rd st at 855 C st citysidewalk by tree L cut			
185	3	1323-1375, 3rd St	\$18.75	3rd st at 855 C st citysidewalk by PG&E box L cut			
186	4	1323-1375, 3rd St	\$25.00	3rd st at 855 C st citysidewalk by PG&E box L cut			
187	0	1301-1321, 3rd St		R&R 3rd st at 855 C st citysidewalk at tree by corner. Slabs are separated at patch	200		
188	0	1301-1321, 3rd St		ATTN 3rd st at 855 C st No Truncated Domes at ped-ramp at corner			
189	0	840, C St		ATTN 3rd st at 840 C st No Truncated Domes at ped-ramp at corner			







190	4	840, C St	\$30.00	3rd st at 840 C st citysidewalk past corner X cut			
191	4	1216, 3rd St	\$30.00	3rd st at 840 C st citysidewalk past corner X cut			
192	0	1216, 3rd St		ATTN 3rd st at 840 C st TV Cable box in citysidewalk needs replacement	6		
193	0	1221, 3rd St		ATTN 1221 3rd st TV Cable box in citysidewalk needs replacement	6		
194	0	1178-1198, 3rd St		ATTN 3rd st at 831 B st No Truncated Domes at ped-ramp at corner			
195	0	1179-1199, 3rd St		ATTN 3rd st at 848 B st No Truncated Domes at ped-ramp at corner			

196	3	1117, 3rd St	\$75.00	1117 3rd st citysidewalk at tree			
197	5	1115, 3rd St	\$31.25	1115 3rd st citysidewalk at PG&E box box L cut			
198	5	1148, 3rd St	\$18.75	1115 3rd st citysidewalk at PG&E box box L cut			
199	0	1115, 3rd St		ATTN 1115 3rd st hole in citysidewalk at Entrance needs fill	0.5		
200	4	1115, 3rd St	\$40.00	1115 3rd st citysidewalk at tree			
201	0	1101, 3rd St		R&R 1101 3rd st citysidewalk at driveway. Slavs have numerous holes in slabs	100	 	



# Third Street Corridor Sidewalk Assessment







03-25-2018







202	3	1101, 3rd St	\$25.00	1101 3rd st citysidewalk at tree past driveway L cut		
203	4	1101, 3rd St	\$25.00	1101 3rd st citysidewalk at tree past driveway L cut X cut		
204	5	1101, 3rd St	\$31.25	1101 3rd st citysidewalk at tree past driveway X cut L cut		
205	3	1101, 3rd St	\$11.25	1101 3rd st citysidewalk at tree past driveway L cut		
206	0	1101, 3rd St		ATTN 1101 3rd st at A st No Truncated Domes at ped-ramp at corner		
207	0	828-898, A St		ATTN 1005 3rd st at A st No Truncated Domes at ped-ramp at corner		



# Third Street Corridor Sidewalk Assessment

03-25-2018








208	3	1033, 3rd St	\$26.25	1005 3rd st citysidewalk at street lighting box L cut		
209	3	1033, 3rd St	\$87.50	1005 3rd st citysidewalk at street lighting box L cut		
210	3	1005, 3rd St	\$87.50	1005 3rd st citysidewalk at tree L cut		
211	3	1005, 3rd St	\$11.25	1005 3rd st citysidewalk at tree L cut		
212	4	1033, 3rd St	\$30.00	1005 3rd st citysidewalk at Pacific Bell Box L cut		
213	3	1033, 3rd St	\$30.00	1005 3rd st citysidewalk at Pacific Bell Box L cut L cut		

214	3	1005, 3rd St	\$22.50	1005 3rd st citysidewalk at Pacific Bell Box L cut L cut		
215	4	1033, 3rd St	\$40.00	1005 3rd st citysidewalk at Pacific Bell Box L cut L cut		
216	7	1005, 3rd St	\$43.75	1003 3rd st citysidewalk at PG&E box L cut		
217	7	1003, 3rd St	\$26.25	1003 3rd st citysidewalk at PG&E box L cut		
218	0	800-898, Brooks St		ATTN 1003 3rd st at Brooks st No Truncated Domes at ped-ramp at corner		
219	4	999, 3rd St	\$15.00	999 3rd st citysidewalk at Street lighting box L cut		


















# Third Street Corridor Sidewalk Assessment

03-25-2018

220	4	999, 3rd St	\$30.00	999 3rd st citysidewalk at Street lighting box L cut		
221	4	999, 3rd St	\$65.00	999 3rd st citysidewalk past sewer cap		
222	0	999, 3rd St		R&R 999 3rd st Lindaro sy citysidewalk at corner. Citysidewalk is cracked Nd sunken at PG&E box and No Truncated Domes at ramp at corner		
223	0	855, 3rd St		ATTN 855 3rd st at Lindaro st No Truncated Domes at ped-ramp at corner		
224	5	855, 3rd St	\$43.75	855 3rd st citysidewalk at driveway		
225	7	855, 3rd St	\$70.00	855 3rd st citysidewalk at driveway		









226	0	12, Ritter St		ATTN 3rd st at 12 Ritter st No Truncated Domes at ped-ramp at corner			
227	0	815, 3rd St		ATTN 815 3rd st at Ritter st No Truncated Domes at ped-ramp at corner			
228	0	815, 3rd St		R&R 815 3rd st citysidewalk at PG&E high voltage box in driveway. Slabs are gapped and utility box raised	160		
229	0	813, 3rd St		ATTN 815 3rd st citysidewalk at PG&E box needs replacement	6		
230	0	815, 3rd St		ATTN 815 3rd st citysidewalk at Pacific Bell box needs replacement	12		
231	0	813, 3rd St		ATTN 815 3rd st hole in citysidewalk at driveway needs fill	1		

232	0	813, 3rd St		R&R 815 3rd st citysidewalk at PG&E box past driveway. Slab is cracked and gapped			
233	5	815, 3rd St	\$175.00	815 3rd st citysidewalk at PG&E high voltage box parallel cut			
234	0	703, 3rd St		R&R 703 3rd st citysidewalk before corner. Slab is sunken Nd piece missing from citysidewalk	250		
235	4	601-603, 3rd St	\$40.00	3rd st at 851 Irwin st citysidewalk at Driveway			
236	4	601-603, 3rd St	\$35.00	3rd st at 851 Irwin st citysidewalk past Driveway			
237	3	601-603, 3rd St	\$15.00	3rd st at 851 Irwin st citysidewalk past Driveway X cut			



# Third Street Corridor Sidewalk Assessment








03-25-2018

238	3	601-603, 3rd St	\$26.25	3rd st at 851 Irwin st citysidewalk past Driveway X cut		
239	5	601-603, 3rd St	\$31.25	3rd st at 851 Irwin st crack in citysidewalk past Driveway L cut		
240	5	601-603, 3rd St	\$50.00	3rd st at 851 Irwin st crack in citysidewalk past Driveway L cut		
241	4	515, 3rd St	\$240.00	515 3rd st citysidewalk at tree before driveway		
242	6	515, 3rd St	\$210.00	515 3rd st citysidewalk at tree past driveway		
243	4	515, 3rd St	\$62.50	515 3rd st citysidewalk at tree past driveway		



# Third Street Corridor Sidewalk Assessment

03-25-2018







244	6	515, 3rd St	\$270.00	515 3rd st citysidewalk at last driveway		
245	8	515, 3rd St	\$160.00	515 3rd st citysidewalk at end of last driveway		
246	0	515, 3rd St		R&R 515 3rd st at Grand ave csw is cracked and No Truncated Domes at ramp at corner		
247	0	900-998, Grand Ave		ATTN 440 3rd st at Grand Ave No Truncated Domes at corner		
248	5	514 1/2, 3rd St	\$25.00	514 3rd st citysidewalk at AT&T box at Telephone pole 80865		
249	5	522A, 3rd St	\$118.75	526 3rd st citysidewalk at fire hydrant Parallel cut		
















# Third Street Corridor Sidewalk Assessment

03-25-2018

250	3	536, 3rd St	\$15.00	534 3rd st citysidewalk by front door	
251	4	536, 3rd St	\$120.00	538 3rd st citysidewalk by front door Parallel Cut	
252	4	901, Irwin St	\$67.50	3rd st at 901 Irwin st citysidewalk past corner	
253	5	901, Irwin St	\$67.50	3rd st at 901 Irwin st citysidewalk by Pacific Telephone box	
254	4	610, 3rd St	\$67.50	610 3rd st citysidewalk at tree	
255	5	610, 3rd St	\$150.00	610 3rd st citysidewalk at parking lot exit	

256	4	US-101 N	\$90.00	3rd st citysidewalk past water meter between pillars			
257	0	666, 3rd St		R&R 666 3rd st citysidewalk at PG&E high voltage box and water meter. Slab at meter is lifted and cracked	50		
258	0	680, 3rd St		R&R 666 3rd st citysidewalk at Corner. No Truncated Domes and curb is cracked parts missing	72		
259	0	706, 3rd St		R&R 706 3rd st citysidewalk at tree. Citysidewalk is cracked and lifted at Water meter	432		
260	0	706, 3rd St		R&R 706 3rd st citysidewalk at tree. Citysidewalk is cracked and lifted	108		
261	0	706, 3rd St		ATTN 706 3rd st CATV box in citysidewalk needs replcement	6		

262	4	768-798, 3rd St	\$25.00	3rd st at 902 Lincoln citysidewalk by sewer cap L cut		
263	3	768-798, 3rd St	\$30.00	3rd st at 902 Lincoln citysidewalk by sewer cap parallel cut L cut		
264	4	810, 3rd St	\$50.00	808 3rd st citysidewalk by water meters parallel cut L cut		
265	3	812, 3rd St	\$7.50	808 3rd st citysidewalk by water meters L cut		
266	5	840, 3rd St	\$125.00	830 3rd st citysidewalk at ramp at crosswalk at Telephone box		
267	0	840, 3rd St		R&R 830 3rd st citysidewalk at driveway. Csw is gapped and curb piece missing		150





268	0 844, 3rd St			ATTN 830 3rd st Pacific Telephone box in citysidewalk is lifted needs replacement	8		
269	0 901-935, Lootens Pl			ATTN 830 3rd st SRFD box in citysidewalk is sunken needs replacement	6		
270	0 999, 3rd St			ATTN 830 3rd st At Lootens Pl. No Truncated Domes at ramp			
271	7 900-998, Lootens Pl	\$105.00		830 3rd st At Lootens Pl. Citysidewalk at ramp at Asphalt patch			
272	0 902, 3rd St			ATTN 902 3rd st At Lootens Pl. No Truncated Domes at ramp			
273	0 902, 3rd St			R&R 926 3rd st citysidewalk at parking garage. Citysidewalk has broken pieces at trip hazards	60		





# Third Street Corridor Sidewalk Assessment








03-25-2018

274	8	902, 3rd St	\$100.00	926 3rd st citysidewalk at asphalt patch at Street light box L cut			
275	5	902, 3rd St	\$43.75	926 3rd st citysidewalk at Street light box L cut X cut			
276	11	902, 3rd St	\$123.75	926 3rd st citysidewalk at tree X cut T cut			
277	5	902, 3rd St	\$25.00	926 3rd st citysidewalk at tree T cut X cut			
278	8	902, 3rd St	\$60.00	926 3rd st citysidewalk at tree X cut			
279	0	902, 3rd St		R&R 926 3rd st citysidewalk at tree at Monitoring Well. Citysidewalk is lifted by roots	125		



# Third Street Corridor Sidewalk Assessment


03-25-2018

280	0	926, 3rd St		R&R 926 3rd st citysidewalk at tree at Driveway. Citysidewalk is lifted by roots	150		
281	4	926, 3rd St	\$40.00	926 3rd st citysidewalk at tree parallel cut L cut			
282	4	926, 3rd St	\$15.00	926 3rd st citysidewalk at tree L cut X cut			
283	4	926, 3rd St	\$10.00	926 3rd st citysidewalk at tree X cut			
284	6	926, 3rd St	\$90.00	926 3rd st citysidewalk at tree			
285	3	926, 3rd St	\$37.50	926 3rd st citysidewalk between trees parallel cut			



# Third Street Corridor Sidewalk Assessment

03-25-2018

286	4	522A, 3rd St	\$20.00	526 3rd st citysidewalk by entrance		
-----	---	--------------	---------	-------------------------------------	---	--