



- ① CONCRETE SHALL BE CLASS 520-C-2500, CONFORMING TO SUBSECTION 201-1 OF THE STANDARD SPECIFICATIONS.
- ② SIDEWALK THICKNESS = 4"
(SEE ALLEY APRON AND DRIVEWAY APPROACH STANDARD PLANS FOR THICKNESS.)
- ③ PROVIDE 1/4" THICK EXPANSION JOINTS PER SECTION 303-5.4.2 OF THE STANDARD SPECIFICATIONS AT THE BC AND EC OF ALL WALK RETURNS, AROUND ALL UTILITY POLES. EXPANSION JOINT MATERIAL SHALL CONFORM TO SUBSECTION 201-3.2 OF THE STANDARD SPECIFICATIONS "PREMOLDED JOINT FILLER".
- ④ TRANSVERSE WEAKENED PLANE JOINTS SHALL BE PROVIDED PER SECTION 303-5.4.3 OF THE STANDARD SPECIFICATIONS.
- ⑤ CONSTRUCT 3'X3' TREE WELLS AT BACK OF CURB PER STD. PLAN NO. 1124 AND AS SHOWN ON PLANS. FOR LARGE TREES EXTEND THE TREE WELLS AS DIRECTED BY THE ENGINEER.
- ⑥ PRESERVE HISTORIC CONCRETE FEATURES. CONTRACTOR SHALL COORDINATE REMOVALS IN THE CIVIC CENTER/DOWNTOWN AREA WITH THE ENGINEER TO ENSURE PRESERVATION OF HISTORIC FEATURES.
- ⑦ LANDSCAPE PER PARKWAY IMPROVEMENT GUIDELINES FOR CASE 1 AND 2.
- ⑧ WHERE THERE ARE RIGHT-OF-WAY OR OTHER CONSTRAINTS, WIDTH "W" MAY BE ADJUSTED AS DIRECTED BY THE ENGINEER.

APPROVED: *[Signature]* DATE: 3.22.16
 CITY ENGINEER

CITY OF SANTA ANA
 PUBLIC WORKS AGENCY



DATE	REVISION

SIDEWALK DETAILS

STD. PLAN NUMBER 1104