



NOTES:

1. THIS DRAWING DOES NOT INDICATE THE NUMBER OF BLOCKS PER SECTION.
2. BLOCK WALL IS TO BE CONSTRUCTED PRIOR TO SIDEWALK CONSTRUCTION.
3. CONCRETE SIDEWALK TO BE PLACED UP TO WALL.
4. ALL BARS TO BE DEFORMED ASTM DESIGNATION A15 AND A305.
5. NO SURCHARGE HAS BEEN PROVIDED FOR IN THE DESIGN OF THIS WALL.
6. CONCRETE BLOCK TO MEET ASTM DESIGNATION C90-52.
7. GROUT TO BE 1 TO 3 MAXIMUM 1/10 PART LIME.
8. GROUTING REQUIRED IN ALL CELLS WITH STEEL.
9. BOTTOM ROW VERTICAL JOINTS LEFT UNMORTARED FOR DRAINAGE.
10. ALL CONCRETE TO BE CLASS "A" PER STATE DIVISION OF HIGHWAYS STANDARD SPECIFICATIONS.
11. HEAVY DUTY WALL MESH 3/16" DIAMETER AT THE SECOND AND FOURTH COURSE FROM TOP.
12. WHEN MINIMUM WALL HEIGHT IS SPECIFIED, HEIGHT SHALL BE MEASURED FROM SIDE HAVING THE HIGHER ELEVATION.
13. DIMENSIONS FOR HEIGHT OF WALL SHOWN HEREON ARE MAXIMUM. HIGHER WALL WILL REQUIRE PLAN AND BUILDING DEPARTMENT APPROVAL.

DATE OF REVISIONS	NATURE OF	CITY OF SANTA ANA IMPROVEMENT STANDARD		STD NO.
5-73	REV. MIN. WALL HT.	4" BLOCK WALL		113
6-73	REV. MAX. WALL HT.			
10-76	REV. NOTE 12.			
		APPROVED: <i>V. V. Foreman</i>	CITY ENGINEER	DATE 10/5/62