



- ① BLOCK WALL SHALL BE CONSTRUCTED PRIOR TO SIDEWALK CONSTRUCTION.
- ② CONCRETE SIDEWALK, IF REQUIRED, TO BE PLACED UP TO WALL.
- ③ WHEN MINIMUM WALL HEIGHT IS SPECIFIED, HEIGHT SHALL BE MEASURED FROM SIDE HAVING THE HIGHER ELEVATION.
- ④ DIMENSIONS FOR HEIGHT OF WALL SHOWN HEREON ARE MAXIMUM. SUBMIT PLAN FOR APPROVAL IF WALL IS HIGHER.
- ⑤ NO SURCHARGE HAS BEEN PROVIDED FOR IN THE DESIGN OF THIS WALL.
- ⑥ OMIT ALTERNATE HEAD JOINTS IN FIRST COURSE FOR DRAINAGE.
- ⑦ POUR POST AND FOOTING AGAINST NATURAL UNDISTURBED EARTH.
- ⑧ CONCRETE MASONRY UNITS SHALL BE GRADE "N" CONFORMING TO ASTM C90.
- ⑨ CONCRETE SHALL BE 500-C-2500.
- ⑩ REINFORCING STEEL SHALL BE DEFORMED BARS GRADE 40 CONFORMING TO ASTM A615.
- ⑪ MORTAR SHALL BE TYPE S OR M AS SPECIFIED IN UBC TABLE 24-A.
- ⑫ GROUTING REQUIRED IN ALL CELLS WITH STEEL.
- ⑬ GROUT SHALL BE 1-PART CEMENT AND 2.25 TO 3-PARTS SAND OR 1-PART CEMENT, 2 TO 3 PARTS SAND AND 1.25 TO 2 PARTS PEA GRAVEL. MAXIMUM 0.10 PART OF LIME MAY BE ADDED.

DATE OF REVISIONS	NATURE OF	CITY OF SANTA ANA IMPROVEMENT STANDARD		STD. NO.
		6" BLOCK WALL		
APPROVED:		<i>Robert E. Eichblatt</i>	CITY ENGINEER	DATE 11/28/84