

Pipe Diameter	A	B	H	Bars "R"			Bars "S"			Bars "T"			Bars "U"		
				No.	Size	Length	No.	Size	Spacing & Length	No.	Size	Length	No.	Size	Length
39"	11"	5'-3"	6'-0"	6	4	4'-11"	1	4	5'-0"	4	4	5'-0"	7	4	5'-0"
42"	11"	5'-6"	6'-3"	6	4	5'-2"	1	4	5'-0"	4	4	5'-0"	7	4	5'-0"
45"	11"	5'-9"	6'-6"	6	4	5'-5"	2	4	4"CTS 5'-0"	4	4	5'-0"	9	4	5'-0"
48"	13"	6'-0"	6'-11"	6	4	5'-8"	3	4	4"CTS 5'-0"	5	4	5'-0"	9	4	5'-0"
51"	13"	6'-3"	7'-2"	6	4	5'-11"	4	4	4"CTS 5'-0"	5	4	5'-0"	9	4	5'-0"
54"	13"	6'-6"	7'-5"	6	5	6'-2"	4	4	4"CTS 5'-0"	5	4	5'-0"	9	4	5'-0"
57"	14"	6'-9"	7'-9"	6	5	6'-5"	4	4	5"CTS 5'-0"	5	4	5'-0"	9	4	5'-0"
60"	14"	7'-0"	8'-0"	6	5	6'-8"	5	4	5"CTS 5'-0"	5	4	5'-0"	11	4	5'-0"
63"	14"	7'-3"	8'-3"	6	6	6'-11"	6	4	5"CTS 5'-0"	6	4	5'-0"	11	4	5'-0"
66"	15"	7'-6"	8'-7"	6	6	7'-2"	6	4	5"CTS 5'-0"	6	4	5'-0"	11	4	5'-0"
69"	15"	7'-9"	8'-10"	6	6	7'-5"	7	4	5"CTS 5'-0"	6	4	5'-0"	11	4	5'-0"
72"	15"	8'-0"	9'-1"	6	6	7'-8"	7	4	5"CTS 5'-0"	6	4	5'-0"	11	4	5'-0"

Pipe Diameter	A	B	H	Bars "V"			Bars "W"			Bars "X"			Bars "Y"		
				No.	Size	Spacing & Length	No.	Size	Length	No.	Size	Length	No.	Size	Length
39"	11"	5'-3"	6'-0"	6	4	12"CTS 5'-6"	5	4	4'-11"	2	4	3'-8"	2	4	3'-4"
42"	11"	5'-6"	6'-3"	6	4	12"CTS 5'-9"	5	4	5'-2"	2	4	4'-0"	2	4	3'-4"
45"	11"	5'-9"	6'-6"	6	4	12"CTS 6'-0"	5	4	5'-5"	2	4	4'-4"	2	4	3'-4"
48"	13"	6'-0"	6'-11"	6	4	12"CTS 6'-5"	6	4	5'-8"	2	4	4'-8"	2	4	3'-4"
51"	13"	6'-3"	7'-2"	6	4	12"CTS 6'-8"	6	4	5'-11"	2	4	5'-0"	2	4	3'-4"
54"	13"	6'-6"	7'-5"	6	4	12"CTS 6'-11"	5	5	6'-2"	2	4	5'-4"	2	4	3'-4"
57"	14"	6'-9"	7'-9"	6	4	12"CTS 7'-3"	5	5	6'-5"	2	4	5'-8"	2	4	3'-4"
60"	14"	7'-0"	8'-0"	6	4	12"CTS 7'-6"	5	5	6'-8"	2	4	6'-0"	2	4	3'-4"
63"	14"	7'-3"	8'-3"	6	4	12"CTS 7'-9"	6	6	6'-11"	2	4	6'-4"	2	4	3'-4"
66"	15"	7'-6"	8'-7"	6	4	12"CTS 8'-1"	6	6	7'-2"	2	4	6'-8"	2	4	3'-4"
69"	15"	7'-9"	8'-10"	6	4	12"CTS 8'-4"	6	6	7'-5"	2	4	7'-0"	2	4	3'-4"
72"	15"	8'-0"	9'-1"	6	4	12"CTS 8'-7"	6	6	7'-8"	2	4	7'-0"	2	4	3'-4"

DATE OF REVISIONS	NATURE OF	CITY OF SANTA ANA IMPROVEMENT STANDARD											STD. NO.
		SCHEDULE OF REINFORCING STEEL TYPES B&C JUNCTION CHAMBERS											909
APPROVED: <i>10/10/62</i>											CITY ENGINEER		DATE <i>10/30/62</i>