




Planning & Building Agency
 Building Safety Division
 20 Civic Center Plaza
 P.O. Box 1988 (M-19)
 Santa Ana, CA 92702
 (714) 647-5800
 www.santa-ana.org

EQUIPMENT SETBACK REQUIREMENT

BLD-07 SAMC

APPLICABLE STANDARDS: Santa Ana Municipal Code (SAMC) Section 41-622.5



LOCATION OF MECHANICAL EQUIPMENT Santa Ana Municipal Code Section 41-622.5

"When located outside of a building, no comfort cooling equipment, mechanical absorption equipment, compressor, pump, pool heater and associated equipment shall be located between a building wall and a side property line."