

TOWN OF SWANSBORO

PUBLIC UTILITIES POLICY--NO. 6
ACETYLENE AND OXYGEN CYLINDERS

To ensure the safety and well being of all public utility employees of Town of Swansboro it shall be policy that all acetylene and oxygen cylinders should be properly secured whether empty or full. A minimum of 20' clearance should be maintained between the two materials.

APPROVED BY THE TOWN MANAGER THIS 10TH DAY OF JANUARY 1990.



William E. Price, Town Manager