

**TAMALPAIS COMMUNITY SERVICES DISTRICT**  
Marin County, California

**CORPORATION YARD FENCE REPLACEMENT - PHASE I**

**Bid Opening: 2:00 PM on October 31, 2023**

**ADDENDUM NO. 1**

**IMPORTANT – RECEIPT OF THIS ADDENDUM SHOULD BE  
ACKNOWLEDGED ON SUPPLIED FORM WITH YOUR BID**

**FAILURE TO DO SO MAY INVALIDATE YOUR BID**

I received THREE (3) page(s) of Addendum material including this page:

Company: \_\_\_\_\_

Signature: \_\_\_\_\_

**TAMALPAIS COMMUNITY SERVICES DISTRICT**  
Marin County, California

**CORPORATION YARD FENCE REPLACEMENT - PHASE I**

**Bid Opening: 2:00 PM on October 31, 2023**

**ADDENDUM NO. 1**

**GENERAL**

The Engineer's Estimate for this project is \$145,000.

**SPECIFICATIONS**

1. **Section 00100, Page 2, First Paragraph, NOTICE INVITING BIDS**

Change the first paragraph to read as follows:

“Bradstreet credit risk rating of ~~3A2~~ **2A2** or better...”.

2. **Section 01010, Page 3, First Paragraph, LIQUIDATED DAMAGES**

Change line five (5) of the first paragraph to read as follows:

“...said specified time or such extension thereof, the sum of five hundred dollars  
(~~\$1,000.00~~) **\$500.00**...”.

3. **Section 02444, Page 2, Paragraph, 2.02-B, PICKETS**

Change the paragraph to read as follows:

“B. Material for pickets shall be *a full 1 inch thick square X 14 Ga. tubing x 8” wide  
Con Heart Redwood boards or better, as noted on the Plans and in Bid Items A-1  
and A-2. in the rail shall be spaced 4.715 inch on center. — Pickets shall have 1 inch  
overlap with no gaps.*”

4. **Section 02444, Page 2, Paragraph, 2.02-C, FENCE POSTS**

Change the paragraph to read as follows:

“C. Fence posts *shall be pressure treated* and gate posts shall be ~~3 inches square X 12~~  
~~Gal~~ *painted steel, 1/4” thick heavy wall.*”

**PLANS**

1. **SHEET 4 OF 6, FENCE DETAIL, NOTES 1**

Change the first paragraph to read as follows:

“ALL POSTS SHALL BE TREATED FIR, *EXCEPT GATE POSTS.*”