



**National Power Corporation**

**PLANT / SYSTEM HOURLY LOAD**

CC Name/No. : Tingloy DPP / 5882033  
 Month : January 01 - 15, 2019  
 Distribution Utility : BATELEC II

Month: Jan 1 - 15, 2020

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0100H	560	380	417	353	355	339		LF	315	303	292	394	301		282
0200H	485	375	350	330	330	328		LF	285	289	279	330	288		273
0300H	440														
0400H	397														
0500H															
0600H															
0700H															
0800H						60							98		
0900H						162							355		
1000H	118	122	150	145	90	374	90	77	126	90	103	249	382	90	154
1100H	473	527	480	437	449	425	316	409	383	444	443	460	379	446	407
1200H	485	530	498	445	442	440	304	470	456	430	450	478	LF	435	412
1300H	467	524	473	440	416	459	418	481	447	426	438	437	112	410	401
1400H	464	520	480	447	LF	466	430	LF	455	431	463	439	226	391	390
1500H	467	530	465	414	102	446	416	483	438	419	444	415	432	396	391
1600H	470	501	480	435	438	435	462	503	440	415	420	404	431	391	387
1700H	487	457	410	396	444	431	472	465	394	419	420	418	430	393	362
1800H	560	543	505	529	545	516	542	544	468	448	500	558	563	455	468
1900H	590	596	568	577	571	575	465	565	551	558	603	600	567	439	510
2000H	595	599	574	571	554	555	530	564	532	557	592	565	541	509	507
2100H	572	569	541	544	491	531	LF	494	499	513	584	494	482	461	474
2200H	500	506	449	498	445	488	LF	419	447	439	509	435	425	390	408
2300H	470	481	432	441	401	419	LF	398	416	368	450	386	364	340	313
2400H	450	458	413	398	391	351	LF	374	372	312	408	356	314	307	294

LF-Line Fault

Note:

PT-Plant Trouble

UM-Unit Under Maintenance

Prepared by:

**G. C. BONQUIN**  
 Senior Engineer

Approved by:

**H. S. AÑO**  
 PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033  
 Month : January 16 - February 15, 2020  
 Distribution Utility : BATELEC II

Month: Jan 16 - 31, 2020

	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
0100H	276	315	315	290	271		276	283	291	241	309	317		295	284	281
0200H	262	297	309	282	263		256	270	276	231	293	299		286	260	263
0300H																
0400H																
0500H																
0600H																
0700H																
0800H					92							217				
0900H					455							325				
1000H	87	150	141	92	400	LF	80	103	174	135	166	350	LM	190	156	172
1100H	418	440	394	416	394	LF	415	381	429	347	381	407	LM	396	420	314
1200H	501	430	413	384	400	393	425	412	412	348	425	413	480	413	412	399
1300H	418	410	421	366	393	386	400	411	400	345	410	425	454	443	421	407
1400H	418	425	404	376	406	434	410	419	414	363	422	431	446	441	454	423
1500H	415	422	406	357	396	419	384	409	384	341	391	445	445	420	421	392
1600H	381	410	403	357	387	423	385	401	413	326	385	440	427	418	421	406
1700H	384	395	395	363	393	382	377	359	404	345	392	391	405	377	412	373
1800H	468	484	499	455	452	435	437	434	484	503	453	426	441	430	437	427
1900H	536	506	519	491	530	520	523	494	497	518	543	527	524	513	538	533
2000H	511	505	511	492	482	488	517	505	499	490	529	514	541	518	514	506
2100H	485	498	458	458	456	445	461	466	LF	476	521	483	480	465	471	459
2200H	445	450	404	390	411	391	408	410	320	422	449	425	420	409	422	383
2300H	403	394	374	315	362	317	355	368	269	376	400	352	380	370	325	301
2400H	358	324	321	300	310	286	298	307	267	321	366	293	310	305	294	271

Month: Feb. 1 - 15, 2020

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0100H	259	256	253		256	298	294	LF	325	250		213	257	289	325
0200H	243	242	240		244	255	278	LF	315	232		217	243	276	309
0300H															
0400H															
0500H															
0600H															
0700H															
0800H			203							212					
0900H			278							326					
1000H	134	127	200	80	128	161	96	170	128	348	118	72	173	154	236
1100H	LF	383	344	377	413	402	440	481	359	377	389	416	405	415	348
1200H	394	391	336	382	405	400	LF	484	384	362	331	409	404	406	362
1300H	417	368	370	379	416	405	405	463	391	374	338	403	378	417	395
1400H	399	360	387	412	429	411	193	449	350	353	398	410	422	428	402
1500H	379	368	397	385	401	418	LF	456	353	361	394	400	403	418	424
1600H	391	384	382	388	421	417	125	429	346	357	370	380	394	369	416
1700H	379	361	360	371	407	389	473	406	395	378	357	369	376	416	429
1800H	438	417	406	439	473	479	497	474	LF	395	400	416	440	489	401
1900H	499	504	470	521	554	526	543	545	195	500	504	522	537	541	399
2000H	472	496	458	507	514	527	LF	555	510	478	LF	508	519	516	437
2100H	438	440	403	451	475	500	LF	530	438	435	LF	438	488	493	569
2200H	404	365	335	386	411	426	LF	500	372	LF	335	391	425	465	558
2300H	297	300	257	298	339	379	LF	425	290	259	250	332	363	394	502
2400H	274	265	236	280	314	310	LF	340	267	235	225	270	347	332	461

LF-Line Fault  
 PT-Plant Trouble  
 UM-Unit Under Maintenance  
 LM-Line Maintenance

Prepared by:  
  
**G. C. BONQUIN**  
 Senior Engineer

Approved by:  
  
**H. S. AÑO**  
 PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033  
 Month : February 16 - March 15, 2020  
 Distribution Utility : BATELEC II

Month: Feb 16 - 29, 2020

	16	17	18	19	20	21	22	23	24	25	26	27	28	29
0100H	428	339		257	275	256	275	307	308		339	314	314	326
0200H	270	321		244	257	231	245	240	289		314	295	297	314
0300H														
0400H														
0500H														
0600H														
0700H														
0800H		97							LF					
0900H		352							LF					
1000H		362	92	135	98	119	116	230	LF	LF	84	LM	88	86
1100H		427	LF	381	392	402	396	388	LF	LF	441	289	438	462
1200H	506	431	442	401	396	375	437	401	LF	LF	446	440	450	443
1300H	472	439	424	389	404	341	423	399	LF	LF	452	450	439	449
1400H	467	455	428	425	414	367	423	393	LF	LF	446	448	441	451
1500H	445	456	413	363	422	349	422	375	LF	168	439	445	422	424
1600H	434	423	410	378	407	343	415	397	LF	511	435	425	425	433
1700H	446	429	408	391	386	309	402	401	550	483	408	436	392	402
1800H	454	457	485	462	428	476	428	428	563	500	471	504	403	463
1900H	573	561	512	537	509	524	555	559	617	617	562	559	543	593
2000H	586	536	500	500	496	490	545	527	584	600	563	550	540	575
2100H	540	511	439	444	449	441	485	500	551	548	535	514	458	549
2200H	488	438	372	391	334	345	464	LF	478	460	450	449	461	512
2300H	420	388	302	348	294	304	345	LF	437	405	368	355	403	461
2400H	364	321	277	290	267	280	330	LF	407	384	337	332	349	425

Month: Mar. 1 - 15, 2020

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0100H	277	261	333	330	345	333	343	461	440		424	419	375	360	424
0200H	253	257		320	319	319	328	409	425		415	384	360	345	406
0300H															
0400H															
0500H															
0600H															
0700H															
0800H		183							235						
0900H		300							363						
1000H	148	449	85	170	150	200	193	147	453	105	117	95	165	107	215
1100H	458	434	471	460	470	430	452	507	484	507	LF	469	465	449	460
1200H	445	411	450	458	458	439	482	496	474	505	441	461	453	446	479
1300H	450	445	462	449	466	430	469	494	492	540	445	469	449	450	470
1400H	449	454	465	460	480	441	495	484	507	538	467	485	451	463	454
1500H	417	SD	470	440	LF	424	497	483	482	526	444	471	455	431	449
1600H	389	SD	456	421	417	404	486	434	453	485	436	452	450	422	432
1700H	409	SD	428	414	405	412	463	448	427	448	412	425	441	413	401
1800H	466	473	447	447	464	425	458	523	474	455	460	435	449	420	426
1900H	600	602	583	567	595	562	644	619	611	635	541	565	564	601	562
2000H	582	587	585	571	582	566	631	618	621	640	548	587	596	590	565
2100H	556	540	545	560	535	541	631	609	606	613	518	570	565	580	542
2200H	500	455	477	494	455	471	616	553	543	533	530	553	505	534	509
2300H	431	380	417	440	401	429	545	494	497	485	480	455	443	480	449
2400H	384	345	390	428	379	386	489	455	470	455	445	394	376	477	421

LF-Line Fault

Note:

- PT-Plant Trouble
- UM-Unit Under Maintenance
- LM-Line Maintenance
- SD- Plant Shutdown

Prepared by:

**G. C. BOMQUIN**  
 Senior Engineer

Approved by:

**H. S. ANO**  
 PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033  
 Month : March 16 - April 15, 2020  
 Distribution Utility : BATELEC II

Month: Mar. 16 - 31, 2020

	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
0100H	396		270	337	373	392	438	411	411	400	415	393	427	437	429	441
0200H	374		260	315	353	372	420	398	398		395	374	373	410	418	413
0300H																
0400H																
0500H																
0600H																
0700H																
0800H	170															187
0900H	260								160							376
1000H	407	41	129	241	210	186	188	188	421	191	187	LM	185	200	198	451
1100H	423	415	424	490	500	495	496	496	484	510	471	358	490	501	517	429
1200H	LF	425	467	459	477	490	489	489	485	500	487	504	484	471	495	437
1300H	391	454	474	450	461	475	453	453	435	443	453	497	435	457	445	442
1400H	410	407	422	440	420	483	446	446	436	465	483	435	442	442	430	437
1500H	390	88	427	440	438	450	445	445	432	437	429	433	428	439	421	452
1600H	361	426	403	418	429	414	411	411	417	462	427	455	432	384	444	454
1700H	LF	424	387	393	390	395	392	392	LF	420	446	442	432	417	438	413
1800H	457	466	431	418	432	435	446	486	317	410	391	521	413	406	436	414
1900H	LF	513	553	551	557	558	563	563	537	553	553	546	566	554	571	550
2000H	LF	492	530	559	570	572	589	589	545	569	549	567	571	569	575	568
2100H	LF	424	499	536	558	553	549	549	514	553	516	539	545	549	569	550
2200H	LF	417	427	479	491	531	503	503	460	493	471	501	501	500	525	535
2300H	LF	316	417	427	450	488	485	485	453	446	445	454	454	468	475	487
2400H	LF	290	350	398	415	464	442	442	432	422	410	420	438	445	441	451

Month: Apr. 1 - 15, 2020

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0100H		445													
0200H		289													
0300H															
0400H															
0500H															
0600H															
0700H															
0800H		205	209	215	250	192	198	195	202	107	67	147	185	157	
0900H		406	440	LF	423	395	412	377	410	415	388	426	441	421	253
1000H	225	450	460	467	448	418	445	403	443	438	424	436	430	442	430
1100H	483	441	450	504	441	408	421	434	459	428	419	447	419	467	491
1200H	476	439	448	470	436	420	446	447	467	458	426	451	448	464	480
1300H	443	457	457	472	448	436	455	442	476	464	430	446	458	488	440
1400H	436	460	LF	461	458	444	443	454	444	455	450	461	463	495	427
1500H	440	LF	450	445	440	428	430	447	461	468	428	437	463	490	424
1600H	454	212	464	461	427	444	450	431	466	444	407	451	435	485	446
1700H	435	429	426	462	422	408	428	430	438	LF	408	425	454	453	431
1800H	398	438	415	413	410	406	407	449	436	434	406	424	426	471	425
1900H	575	585	580	555	539	556	565	575	561	578	544	572	565	LF	LF
2000H	583	601	594	564	551	557	575	595	586	588	564	566	572	LF	492
2100H	559	470	564	539	540	546	557	586	584	567	541	559	565	508	479
2200H	533	514	511	488	500	516	501	544	524	534	512	542	528	464	427
2300H	470	502	492	469	482	477	483	556	515	528	494	529	411	449	LF
2400H	440	447	463	443	446	435	442	465	500	499	473	480	477	416	LF

LF-Line Fault  
 PT-Plant Trouble  
 UM-Unit Under Maintenance  
 LM-Line Maintenance  
 SD- Plant Shutdown

Note:

Prepared by:

**G. C. BOMQUIN**  
 Senior Engineer

Approved by:

**H. S. AÑO**  
 PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033
Month : April 16 - May 15, 2020
Distribution Utility : BATELEC II

Month: Apr. 16 - 30, 2020

Table with 15 columns (hours 16-30) and 24 rows (0100H-2400H) showing hourly load data for April 16-30, 2020.

Month: May. 1 - 15, 2020

Table with 15 columns (hours 1-15) and 24 rows (0100H-2400H) showing hourly load data for May 1-15, 2020.

LF-Line Fault
PT-Plant Trouble
UM-Unit Under Maintenance
LM-Line Maintenance
SD- Plant Shutdown

Note:

Prepared by:

G. C. BOMQUIN
Senior Engineer

Approved by:

H. S. ANO
PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033
Month : May 16 - Jun 15, 2020
Distribution Utility : BATELEC II

Month: May. 16 - 31, 2020

Table with 16 columns (hours 16-31) and 24 rows (hours 0100H-2400H) showing hourly load data for May 16-31, 2020.

Month: Jun. 1 - 15, 2020

Table with 15 columns (hours 1-15) and 24 rows (hours 0100H-2400H) showing hourly load data for Jun 1-15, 2020.

LF-Line Fault
PT-Plant Trouble
UM-Unit Under Maintenance
LM-Line Maintenance
SD- Plant Shutdown

Prepared by:

G. C. BOMQUIN
Senior Engineer

Approved by:

H. S. AÑO
PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033  
 Month : Jun 16 - Jul 15, 2020  
 Distribution Utility : BATELEC II

Month: Jun. 16 - 30, 2020

	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
0100H	461	499	284	287	LF	257	285	313	LF	347	334	LF	289	266	294
0200H	440	483	273	260	LF	249	276	299	LF	329	321	LF	274	251	278
0300H															
0400H															
0500H															
0600H															
0700H															
0800H															
0900H															
1000H	99	LM	98	119	LM	LM	67	93	69	76	92	LM	65	371	139
1100H	435	LF	403	345	430	338	345	339	LF	364	356	349	318	419	304
1200H	431	546	398	335	435	350	371	342	399	375	342	338	354	450	300
1300H	442	545	405	324	431	340	360	351	381	378	337	325	345	498	365
1400H	541	559	411	331	434	345	370	344	386	381	328	328	342	PT	466
1500H	524	534	397	331	LF	322	364	340	384	378	313	329	337	PT	342
1600H	507	528	374	LF	352	289	333	327	364	354	310	317	315	PT	324
1700H	460	LF	331	185	334	300	303	305	335	328	287	288	345	PT	292
1800H	418	524	307	355	359	285	278	294	326	296	LF	281	356	PT	286
1900H	577	600	391	LF	411	381	372	571	404	418	378	390	394	439	369
2000H	LF	LF	408	LF	371	406	415	417	406	425	405	117	420	418	408
2100H	624	363	426	LF	365	410	411	410	400	422	LF	LF	389	4000	405
2200H	609	340	360	LF	266	LF	400	312	403	399	378	368	359	371	376
2300H	559	310	336	LF	285	LF	LF	353	375	378	353	340	293	330	337
2400H	LF	290	301	LF	275	301	330	LF	355	116	325	309	270	307	283

Month: Jul. 1 - 15, 2020

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0100H	278	321	303	320	LF	302	337	LF	315	LF	LF	475	428	406	465
0200H	270	309	287	295	LF	296	324	LF	305	LF	LF	455	400	381	437
0300H															
0400H															
0500H															
0600H															
0700H															
0800H															
0900H															
1000H	LM	61	75	offset 30min.	74	113	73	LM	75	104	108	123	LM	94	100
1100H	377	349	375	350	318	372	435	LF	398	516	455	476	424	LM	377
1200H	412	388	406	370	322	388	416	343	401	LF	494	493	451	490	390
1300H	425	356	419	382	315	383	418	355	411	LF	499	488	471	521	414
1400H	430	392	417	387	302	440	411	337	398	504	503	501	478	510	400
1500H	419	366	392	358	302	383	401	327	397	537	496	434	479	497	394
1600H	404	343	380	323	277	347	391	318	364	504	465	406	450	472	385
1700H	381	303	339	332	272	302	355	294	349	464	LF	398	415	425	420
1800H	295	320	332	349	261	331	321	281	473	454	LF	165	388	602	472
1900H	397	412	426	430	367	417	437	375	599	594	492	573	546	648	575
2000H	410	430	416	424	390	428	462	400	648	624	609	620	582	648	345
2100H	LF	440	403	425	392	412	447	402	644	635	601	LF	566	622	634
2200H	348	418	272	LF	366	392	LF	383	614	LF	565	483	531	579	591
2300H	359	418	357	LF	336	LF	419	344	549	LF	522	461	LF	530	544
2400H	331	318	333	LF	319	353	404	327	531	LF	498	451	429	490	507

LF-Line Fault  
 PT-Plant Trouble  
 UM-Unit Under Maintenance  
 LM-Line Maintenance  
 SD- Plant Shutdown

Note:

Prepared by:

**G. C. BOMQUIN**  
 Senior Engineer

Approved by:

**H. S. ANO**  
 PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033  
 Month : Jul. 16 - Aug. 15, 2020  
 Distribution Utility : BATELEC II

Month: Jul. 16 - 31, 2020

	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
0100H	487	472	479	LF	391	347	359	LF	492	463	442	469	361	LF	412	360
0200H	463	459	461	LF	366	328	343	LF	LF	LF	411	449	339	LF	398	339
0300H																
0400H																
0500H																
0600H																
0700H																
0800H																
0900H																
1000H	231	120	253	109	95	97	199	LM	60	211	98	104	114	158	105	101
1100H	465	492	469	448	457	441	LM	LM	444	477	LF	526	494	493	454	440
1200H	477	484	533	467	473	449	LM	LM	494	479	LF	520	LF	478	477	431
1300H	485	484	477	451	457	451	LM	LM	489	486	355	528	490	482	481	429
1400H	512	499	460	455	459	447	499	LM	504	493	524	532	488	496	487	422
1500H	512	473	466	411	450	392	515	LM	500	485	492	532	471	484	LF	415
1600H	452	453	406	387	423	417	460	LM	463	465	479	506	448	469	304	414
1700H	394	410	390	399	388	420	431	LM	420	379	450	454	414	425	397	400
1800H	387	403	413	382	380	438	398	189	472	451	509	459	456	430	407	LF
1900H	552	463	562	538	536	540	556	655	576	532	LF	613	LF	570	477	582
2000H	603	610	621	599	546	514	579	682	615	560	LF	LF	525	599	538	592
2100H	601	609	612	507	LF	488	567	637	603	596	604	LF	LF	584	504	567
2200H	568	577	564	537	468	437	250	591	565	LF	564	446	451	546	452	499
2300H	515	532	521	486	LF	391	482	539	511	484	519	413	446	487	405	449
2400H	494	504	394	457	363	374	447	507	483	454	486	385	410	450	375	435

Month: Aug. 1 - 15, 2020

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0100H	LF	382	397	437	431	LF	390	354	290	256	370	LF	414	312	LF
0200H	LF	350	367	400	415	LF	LF	335	266	249	356	LF	389	290	LF
0300H															
0400H															
0500H															
0600H															
0700H															
0800H															
0900H															
1000H	101	95	109	LM	176	100	70	105	98	63	97	105	105	108	91
1100H	460	410	419	476	403	486	463	441	388	451	LF	505	444	455	458
1200H	440	384	514	LF	418	472	467	398	420	428	475	485	440	466	462
1300H	419	390	LF	LF	497	511	419	LF	383	441	471	490	484	463	469
1400H	392	373	LF	527	484	504	424	333	219	468	474	488	478	459	451
1500H	405	397	488	534	489	495	414	336	382	465	455	490	LF	447	434
1600H	393	397	529	487	446	457	419	333	365	484	408	450	455	440	440
1700H	415	403	484	465	426	453	131	344	LF	496	378	407	396	438	LF
1800H	416	422	485	432	407	439	416	388	LF	490	LF	395	493	472	545
1900H	535	549	598	581	554	564	534	LF	427	563	565	582	535	LF	LF
2000H	549	567	662	615	597	586	517	461	533	561	610	579	525	594	572
2100H	527	549	600	607	573	567	486	448	507	535	545	561	500	579	570
2200H	476	520	545	575	528	505	447	392	LF	492	493	534	399	572	527
2300H	418	471	496	LF	490	447	401	345	LF	439	426	465	368	399	478
2400H	390	LF	450	453	461	416	381	328	273	392	LF	436	329	358	406

LF-Line Fault  
 PT-Plant Trouble  
 UM-Unit Under Maintenance  
 LM-Line Maintenance  
 SD- Plant Shutdown

Prepared by:  
  
**G. C. BOMQUIN**  
 Senior Engineer

Approved by:  
  
**H. S. AÑO**  
 PEC, Tingloy DPP





National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033  
 Month : Aug. 16 - Sept. 15, 2020  
 Distribution Utility : BATELEC II

Month: Aug. 16 - 31, 2020

	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
0100H	386	407	385	405	358	397	392	384	419	405	425	440	442	504	452	360
0200H	359	376	367	387	338	379	380	363	395	383	402	424	422	460	442	336
0300H																
0400H																
0500H																
0600H																
0700H																
0800H																
0900H																
1000H	97	100	89	94	195	98	95	93	101	208	246	196	250	LF	207	209
1100H	498	489	495	467	427	425	458	461	493	481	492	496	500	175	442	431
1200H	497	516	499	482	428	413	467	467	503	476	494	507	485	408	462	450
1300H	481	502	480	492	433	425	465	454	496	471	504	515	500	489	450	456
1400H	483	505	460	456	432	407	488	460	491	485	490	503	488	485	428	470
1500H	437	487	446	445	428	414	455	435	486	448	481	495	500	470	380	451
1600H	407	454	422	439	420	393	424	418	461	444	458	459	452	LF	365	418
1700H	407	408	432	426	419	379	413	411	438	PT	426	419	425	165	378	372
1800H	405	415	462	469	501	415	421	446	407	446	443	422	455	542	460	377
1900H	602	616	LF	585	585	570	550	565	549	603	605	595	619	632	570	533
2000H	615	623	539	560	592	596	LF	572	561	645	630	643	635	631	580	551
2100H	561	588	599	LF	565	580	495	588	543	644	632	630	645	630	526	552
2200H	540	516	557	406	541	547	509	533	520	574	585	597	610	568	435	525
2300H	490	492	496	403	483	490	478	483	453	524	535	535	554	531	399	461
2400H	457	413	473	379	415	453	408	445	427	486	505	501	530	497	374	431

Month: Sept. 1 - 15, 2020

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0100H	411	433	LF	447	439	514	450	430	441	437	436	427	330	411	405
0200H	389	409	LF	435	421	446	425	408	415	416	413	405	313	LF	381
0300H															
0400H															
0500H															
0600H															
0700H															
0800H															
0900H															
1000H	213	211	165	222	210	252	175	210	234	251	292	203	246	185	298
1100H	480	503	445	525	466	488	555	477	494	502	477	LF	425	510	454
1200H	494	518	495	520	472	480	531	492	476	496	499	LF	446	518	442
1300H	497	507	510	519	497	473	520	476	488	501	485	403	421	495	430
1400H	491	503	482	498	499	465	515	LF	485	507	476	410	445	469	427
1500H	LF	489	475	505	499	447	465	362	469	495	475	394	437	455	405
1600H	425	463	LF	455	435	436	455	460	442	443	423	376	392	442	400
1700H	406	438	440	425	405	405	531	433	436	417	432	393	364	415	407
1800H	403	413	599	471	443	500	630	420	441	525	LF	468	422	511	420
1900H	586	605	625	610	616	607	644	647	614	636	600	530	581	594	552
2000H	612	627	647	512	LF	632	625	LF	642	625	621	542	590	597	565
2100H	610	624	633	587	627	616	570	641	617	628	561	510	572	596	520
2200H	581	584	592	567	582	580	539	605	567	579	520	422	555	549	LF
2300H	512	537	515	522	548	560	494	539	535	535	515	379	480	496	343
2400H	486	492	495	459	533	513	477	496	490	512	446	344	442	438	306

LF-Line Fault  
 PT-Plant Trouble  
 UM-Unit Under Maintenance  
 LM-Line Maintenance  
 SD- Plant Shutdown

Prepared by:

**G. C. BOMQUIN**  
 Senior Engineer

Approved by:

**H. S. AÑO**  
 PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033
Month : Sept. 16 - Oct. 15, 2020
Distribution Utility : BATELEC II

Month: Sept. 16 - 30, 2020

Table with 15 columns (hours 16-30) and 24 rows (0100H-2400H) showing hourly load data for Sept. 16-30, 2020.

Month: Oct. 1 - 15, 2020

Table with 15 columns (hours 1-15) and 24 rows (0100H-2400H) showing hourly load data for Oct. 1-15, 2020.

LF-Line Fault
PT-Plant Trouble
UM-Unit Under Maintenance
LM-Line Maintenance
SD- Plant Shutdown

Note:

Prepared by:

G. C. BOMQUIN
Senior Engineer

Approved by:

H. S. ANO
PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033  
 Month : Oct. 16 - Nov. 15, 2020  
 Distribution Utility : BATELEC II

Month: Oct. 16 - 31, 2020

	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
0100H	338	351	377	357	371	LF	314	358	380	336	LF					
0200H	330	336	367	343	350	LF	301	341	361	316	LF					
0300H																
0400H																
0500H																
0600H																
0700H																
0800H																
0900H																
1000H	240	220	271	246	253	201	241	LF	245	145						
1100H	422	430	418	LF	410	396	408	160	427	335						
1200H	418	LF	420	394	375	372	413	377	436	324						
1300H	414	425	427	398	370	368	443	487	443	357						
1400H	425	434	424	397	341	382	418	428	438	357						
1500H	420	LF	408	394	LF	365	405	429	409	362						
1600H	390	376	391	368	333	401	380	389	LF	395						
1700H	369	399	407	415	380	418	361	381	491	398						
1800H	499	553	541	505	524	545	498	514	561	456						
1900H	569	572	580	571	580	523	536	566	LF	468						
2000H	561	594	567	559	508	512	553	580	LF	458						
2100H	541	548	527	531	462	467	537	561	486	396						
2200H	478	508	471	498	366	395	492	515	408	363						
2300H	410	426	406	460	343	LF	432	436	379	LF						
2400H	375	393	375	392	324	335	382	401	353	LF						

Month: Nov. 1 - 15, 2020

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0100H															
0200H															
0300H															
0400H															
0500H															
0600H															
0700H															
0800H															
0900H															
1000H															
1100H															
1200H															
1300H															
1400H															
1500H															
1600H															
1700H															
1800H															
1900H															
2000H															
2100H															
2200H															
2300H															
2400H															

LF-Line Fault  
 PT-Plant Trouble  
 UM-Unit Under Maintenance  
 LM-Line Maintenance  
 SD- Plant Shutdown

Prepared by:

**G. C. BOMQUIN**  
 Senior Engineer

Approved by:

**H. S. AÑO**  
 PEC, Tingloy DPP



National Power Corporation

PLANT / SYSTEM HOURLY LOAD

CC Name/No. : Tingloy DPP / 5882033  
 Month : Nov. 16 - Dec 15, 2020  
 Distribution Utility : BATELEC II

Month: : Nov. 16 - 30, 2020

	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
0100H						137	130	165	186	198	200	245	256	273	234
0200H						134	125	158	180	190	187	235	244	265	216
0300H															
0400H															
0500H															
0600H															
0700H															
0800H															
0900H															
1000H					LM	LM	LM	LF	130	105	LM	230	LM	193	178
1100H					LM	LM	147	LF	230	203	260	216	LM	288	281
1200H					LM	LM	LF	LF	242	210	268	281	268	286	279
1300H					LM	145	207	LF	254	230	271	270	306	283	283
1400H					LM	149	204	LF	248	207	LF	264	LF	279	264
1500H					LM	140	201	198	226	203	268	243	193	264	260
1600H					LM	148	278	206	219	202	251	250	301	242	244
1700H					102	142	207	LF	211	199	254	263	297	237	LF
1800H					LF	183	280	LF	288	316	352	346	394	350	LF
1900H					LF	LF	277	270	290	319	379	360	375	370	LF
2000H					214	185	271	285	295	327	363	364	358	362	345
2100H					210	189	260	266	281	281	346	345	333	346	317
2200H					185	170	218	243	255	253	318	318	341	LF	284
2300H					164	153	190	215	231	224	LF	282	314	266	251
2400H					152	141	170	200	210	210	256	268	292	247	231

Month: : Dec. 1 - 15, 2020

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0100H	210	263	313	302	266	304	322	LF	293	301	330	334	340	337	319
0200H	195	246	295	288	255	290	LF	LF	281	280	380	317	325	315	297
0300H															
0400H															
0500H															
0600H															
0700H															
0800H															
0900H															
1000H	159	160	LM	221	254	173	LF	238	195	187	249	187	231	216	290
1100H	307	320	297	344	370	356	LF	367	383	386	382	383	386	PT	375
1200H	282	LF	363	325	369	368	330	354	404	370	383	382	385	PT	380
1300H	287	346	368	306	381	368	387	352	403	317	402	390	385	410	415
1400H	292	342	380	315	368	367	393	328	424	322	377	380	394	430	435
1500H	279	319	356	295	350	337	373	343	376	312	369	370	383	405	400
1600H	261	315	337	384	362	315	356	322	357	295	335	343	340	365	390
1700H	281	324	347	328	422	315	371	335	368	298	314	330	336	LF	375
1800H	LF	456	473	444	473	456	LF	452	486	438	450	457	459	LF	450
1900H	420	467	479	455	466	512	421	463	506	422	474	495	491	466	476
2000H	414	475	LF	431	458	493	447	445	486	446	490	499	494	441	473
2100H	379	431	443	409	436	448	436	427	453	413	462	479	481	437	428
2200H	345	392	LF	LF	385	410	386	380	393	362	426	426	438	396	402
2300H	319	347	342	293	345	359	351	337	349	326	370	397	390	355	356
2400H	288	328	331	281	318	341	331	318	322	312	348	357	356	334	327

LF-Line Fault

Note:

PT-Plant Trouble

UM-Unit Under Maintenance

LM-Line Maintenance

SD- Plant Shutdown

Prepared by:

**G. C. BOMQUIN**  
 Senior Engineer

Approved by:

**H. S. ANO**  
 PEC, Tingloy DPP



**National Power Corporation**

**PLANT / SYSTEM HOURLY LOAD**

CC Name/No. : Tingloy DPP / 5882033  
 Month : Dec 16, 2020 - Jan 15, 2020  
 Distribution Utility : BATELEC II

Month: Dec. 16 - 31, 2020

Month:	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
0100H	313		320	297	270	293	335	340	365	406	349	313	318	355	400	LF
0200H	296		300	290	248	283	309	325	350	373	341	304	299	350	365	LF
0300H										354	321					
0400H										336	297					
0500H										330						
0600H										330						
0700H										290						
0800H	250								LF	275						214
0900H	300								315	280						380
1000H	350	275	200	LF	225	LM	275	246	362	320	263	263	210	255	255	384
1100H	380	400	398	270	395	348	415	398	395	330	385	385	415	435	430	380
1200H	360	385	395	355	415	395	420	400	411	350	412	417	412	431	422	400
1300H	380	355	385	350	384	395	410	386	419	390	LF	381	418	420	432	390
1400H	390	345	370	330	360	390	420	389	424	375	346	392	398	432	447	382
1500H	380	345	380	325	350	395	410	390	410	357	379	360	380	421	450	360
1600H	360	327	354	LF	314	355	405	380	405	342	380	350	366	410	437	345
1700H	348	335	349	229	347	355	403	370	405	348	410	370	370	369	448	380
1800H	455	445	446	308	473	476	495	469	530	500	LF	523	498	485	571	526
1900H	480	471	462	414	505	517	514	523	575	536	510	526	531	553	600	LF
2000H	496	481	456	416	483	525	519	532	578	531	508	510	539	560	599	576
2100H	460	462	429	394	430	473	497	521	564	511	475	499	516	558	573	557
2200H	413	402	380	349	LF	413	432	487	523	470	388	409	470	515	528	532
2300H	370	363	346	LF	345	370	386	418	494	390	359	363	405	463	476	507
2400H	341	337	320	293	310	351	359	388	467	370	330	336	370	405	433	510

LF-Line Fault  
 PT-Plant Trouble  
 UM-Unit Under Maintenance  
 LM-Line Maintenance  
 SD- Plant Shutdown

Note:

Prepared by:

**G. C. BOMQUIN**  
 Senior Engineer

Approved by:

**H. S. ANO**  
 PEC, Tingloy DPP