

Test Verification of Conformity

Verification Number: 221116038GZU-VOC001

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Zucchetti Centro Sistemi SpA Via Lungarno 305/A 52028 Terranuova Bracciolini (AR), Italy
Product Description:	Hybrid Inverter
Models/Type References:	AZZURRO 1PH HYD3000 ZP1, AZZURRO 1PH HYD3680 ZP1, AZZURRO 1PH HYD4000 ZP1, AZZURRO 1PH HYD4600 ZP1, AZZURRO 1PH HYD5000 ZP1, AZZURRO 1PH HYD6000 ZP1
Ratings & Principle Characteristics:	See Appendix
Brand Name:	
Relevant Standards/Directives:	EN IEC 61000-6-3:2021 EN IEC 61000-6-1:2019 EMC Directive 2014/30/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China
Date of Tests:	-
Test Report Number(s):	221116038GZU-001
Additional information in Appendix.	



Signature

Name: Sky Zhu

Position: Team Leader

Date: 01 March 2023

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 221116038GZU-VOC001

Ratings & Principle Characteristics:

MODEL	AZZURR O 1PH HYD300 O ZP1	AZZURR O 1PH HYD368 O ZP1	AZZURR O 1PH HYD400 O ZP1	AZZURR O 1PH HYD460 O ZP1
Max.DC input voltage	550Vdc			
MPPT voltage range	85~520Vdc			
Max.PV Isc	2*22.5A			
Rated battery voltage	400V			
Max.charging/discharging current	20A			
Max.charging/discharging power	3000W	3680W	4000W	4600W
Rated grid voltage	230V,50Hz			
Rated output voltage	230V,50/60Hz			
Max.output current	15A	16A	20A	20.9A
Power Factor	1 default (adjustable+/-0.8)			
Rated output power	3000W	3680W	4000W	4600W
Backup Rated Current	13A	16A	17.4A	20A
Backup Rated Apparent Power	3000VA	3680VA	4000VA	4600VA
Ambient Temperature	-10~ +50°C			
Protection Degree	IP65			
Protection Class	Class I			
Inverter topology	Non-Isolated			
Overvoltage Category	AC III, DC II			
Firmware version:	V000001			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

MODEL	AZZURRO 1PH HYD5000 ZP1	AZZURRO 1PH HYD6000 ZP1
Max.DC input voltage	550Vdc	
MPPT voltage range	85~520Vdc	
Max.PV Isc	2*22.5A	
Rated battery voltage	400V	
Max.charging/discharging current	20A	
Max.charging/discharging power	5000W	6000W
Rated grid voltage	230V,50Hz	
Rated output voltage	230V,50/60Hz	
Max.output current	25A	30A
Power Factor	1 default (adjustable+/-0.8)	
Rated output power	5000W	6000W
Backup Rated Current	21.7A	26A
Backup Rated Apparent Power	5000VA	6000VA
Ambient Temperature	-10~ +50°C	
Protection Degree	IP65	
Protection Class	Class I	
Inverter topology	Non-Isolated	
Overvoltage Category	AC III, DC II	
Firmware version:	V000001	



Signature

Name: Sky Zhu

Position: Team Leader

Date: 01 March 2023

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.