Texas Department of Criminal Justice

Bobby Lumpkin
Executive Director

Contracts and Procurement Department

AMENDMENT No. 1

BID NO.:	IW267236
PURCHASER / CONTRACT SPECIALIST:	Keyanna Billard
BID OPENING DATE & TIME:	11/10/2026 @ 03:00 PM
REVISED BID OPENING DATE & TIME:	

The purpose of this amendment is to provide answers to questions.

Reference attached pages of this amendment.

IN THE SUBMISSION OF BID, BIDDER MUST ACKNOWLEDGE RECEIPT OF THIS AMENDMENT; OTHERWISE, THE BID MAY NOT BE GIVEN CONSIDERATION. BIDDER MAY ACKNOWLEDGE RECEIPT ON FACE OF BID OR BY RETURNING ONE COPY OF THIS NOTICE.

SIGNED: _____

BIDDER

COMPANY NAME: _____

Amendment No. 1
Bid No.: IW267236

Question No.	Question	Answer
1	Would you accept an alternate price along with the Bid price to upgrade each of these noted cabinet locations? Or do you want the cabinets included in the final Bid Price for the 4 buildings?	Yes, upload alternate bids in the section stating alternate bid submittal.
2	Upon discovery from the site visit there were several locations missing field wire and the devices for the Intercom and Paging speakers in the dayrooms. The bid documents define the system to support the overall count of devices identified in the details, so just to clarify that the field wire to these devices "other than the 32 intercoms noted in the scope of work" will be excluded in the full bid package. The pass-fail test results of the system from the awarded contractor will be turned over to the facility to determine if the devices will be added to the contract or to be addressed by the facility maintenance at a separate date? Is this correct?	Please include an estimated amount to fix the missing field wire also.
3	Please confirm we do not have to paint the control panel relay cabinet enclosures that we are reusing.	Not Required
4	Is it acceptable to have a stand alone intercom system. Deleting the controls from the new face plate and having a phone style intercom control station in the picket.	No

5	Section 28 80 01- cells security control system. Is this section applicable to the job? Where are these located? Or, is the computer station in place because one of the existing control panel with switches quit working.	Yes, The VFD can be connected to an exhaust fix. The standard will allow you to better understand TDCJ functions we need, understanding and by incorporating the TDCJ standards with basic free world standards. Ignore the liquid pump on the drawing it should have been deleted.
6	SECTION 28 31 10 – FIRE ALARM SYSTEMS. Is this section applicable to the job? Portions of it.	Yes, same as 5
7	Is your current fire alarm vendor going to relocate the fire alarm pulls off of the existing door control consoles?	No

Briscoe Unit - SITE VISIT ATTENDENCE
Solicitation: IW267236
DATE: 10/22/2026
TIME: 10:00 AM

Name *(please print)*	Company	Telephone	Signature	E-Mail
Keyanna Billard	TDCJ	936-437-3875		
Yolanda Crawford	TDCJ	936-437-3832		Yolanda.Crawford@tdcj.texas.gov
Timothy Kiersz	TDCJ	936-4377-273		Timothy.Kiersz@tdcj.texas.gov
Martha Vargas	TDCJ	830-965-4444		Martha.Vargas@tdcj.texas.gov
Cedric Washington	TDCJ	(830) 965-4444		
Chris Goll	CML Security			cgoll@cmlsecurity.us
DARWIN KATAN	CML Security	210.467.9251		dkatan@cmlsecurity.us
Abe Trevino	Vertex Electrical Contractors LLC	512- 981-5368		abe@vertexelectricaltx.com
Ruben Perez	Vertex Electrical Contractors LLC			