Link Nova Scotia
5151 George Street, Suite 1000
Halifax, NS B3J 1M5

Date: Thursday, October 22, 2026

ADDENDUM # 01 for LNS-2627-003

RFC for ALM Campus Asphalt Replacement & Fence Installation

The following Questions are to be noted in the document referenced above.

1.0 Questions:

1.1 Question: It's noted that we need to perform our own locates. Are there any known underground utilities on the property?

Answer: Yes, there are underground utilities that run through the property which include, but are not limited to, Natural Gas, Power, Communication, Steam lines (no longer in use), and a Water Main. As per "Appendix B – RFC Particulars", item B.1.1.1, underground locates will need to be completed by the successful contractor prior to commencing construction to properly identify and locate any items that are present.

The following Clarifications are to be noted in the document referenced above.

2.0 Clarifications:

2.1 In Appendix B, item B.1.3.4.a, Add the following:

"i) Basis of design for the ornamental commercial-grade fencing is the **Nuvo Iron - Nuvo XIII** fence system.

Standard panel width selection must be the 96" (2438mm), with height to meet requirement in B.1.3.1."

2.2 In Appendix B, item B.1.4.3, Add the following:

"a) Block types to be the following description and size:

i) Full, Double-sided Decorative Face with Flat Top.
Dimensions: 60" (L) x "(W) x 30" (H)

ii) Full, Double-sided Decorative Face with Nubs.
Dimensions: 60" (L) x "(W) x 30" (H)"

Link Nova Scotia
5151 George Street, Suite 1000
Halifax, NS B3J 1M5

2.3 In Appendix B, change item B.1.10.1 to read as follows:

"1. Where the Bid Documents stipulate a particular product, alternatives will be considered by the LNS up to five (5) working days before the Bid Closing Date and Time."

This addendum **WILL NOT** require a revision to the Closing Date and Time, or other dates given in the ITT Instructions document and previous addendum. **The deadline for questions will remain October 27, 2026, and the closing date will remain November 3, 2026, at 2:00:59 PM (AT).**

In accordance with Section C.1.4 of Appendix C - Submission Form, the proponent is deemed to have read and taken into account all addenda issued by Link Nova Scotia.

END OF ADDENDUM # 01