	Sma	all Wall-fired E	Boilers (<100 MN					
MONTHLY FUEL USE								
Month	Consumption (GJ)	Consumption (m ³)	% of Total Consumption					
JANUARY	A	1,996,892	14%					
FEBRUARY		1,845,486	13%					
MARCH		1,578,920	11%					
APRIL		1,067,523	8%					
MAY		803,858	6%					
JUNE		268,804	2%					
JULY		450,260	3%					
AUGUST		475,331	3%					
SEPTEMBER		637,701	5%					
OCTOBER		1,179,004	8%					
NOVEMBER		1,563,660	11%					
DECEMBER		2,022,937	15%					
Total Annual Consumption	0.00	13,890,376.00	100%					
Total Smog Period Consumption	0.00	2,635,954.00	19%					

U/hr Heat Input)				
POLLUTION	CONTROL DEVICE			
Selection	NO _√ (as NO ₂)	co		
Colcolon	(lb/MMBTU)	(lb/MMBTU)		
Uncontrolled	0.098	0.082		

ADDITIONAL INFORMATION						
Do you want to use Company-Specific Emission Factors?	NO					
Is the Stack Height ≥50 m Above Grade?	NO					

Click Here to Enter Company-Specific Emission Factor(s)

Total Annual Consumption	523223.20	
(GI)		- 1

NPRI PART 4 CRITERIA AIR CONTAMINANTS (CACs) - EMISSION SUMMARY TABLE																		
ANNUAL FACILITY-WIDE REPORTING																		
CONTAMINANT NAME	CAS#	TOTAL ANNUAL AIR RELEASES FROM NATURAL GAS COMBUSTION ANNUAL AIR RELEASES FROM OTHER SOURCES (including ROAD DUST) (Will be distributed equally across each of the twelve months)			MONTHLY BREAKDOWN OF TOTAL ANNUAL AIR RELEASES BY PERCENTAGE										TOTAL ANNUAL FACILITY WIDE AIR RELEASES			
Carbon Monoxide	630-08-0	40				JAN 14.38%	FEB 13.29%	MAR 11.37%	7.69%	MAY 5.79%	JUN 1.94%	JUL 3.24%	AUG 3,42%	SEP 4.59%	OCT 8.49%	NOV 11.26%	DEC 14.56%	40
	11104-93-1	19	tonnes		tonnes	14.38%	13.29%	11.37%	7.69%	5.79%	1.94%	3.24%	3.42%	4.59%	8.49%	11.26%	14.56%	19 22
Oxides of Nitrogen (expressed as NO ₂)	NA - M09	22	tonnes		tonnes	14.38%	13.29%	11.37%	7.69%	5.79%	1.94%	3.24%	3.42%	4.59%	8.49%	11.26%	14.56%	0.052
PM ₁₀	NA - M10	0.052				14.38%	13.29%	11.37%	7.69%	5.79%	1.94%	3.24%	3.42%	4.59%	8.49%	11.26%	14.56%	0.052
PM _{2.5}		0.052	tonnes		tonnes	121774				10000000								
Sulphur Dioxide	7446-09-5	0.13	tonnes		tonnes	14.38%	13.29%	11.37%	7.69%	5.79%	1.94%	3.24%	3.42%	4.59% 4.59%	8.49% 8.49%	11.26%	14.56%	0.13
Total Particulate Matter	NA - M08	0.052	tonnes		tonnes	14.38%	13.29%	11.37%	7.69%	5.79%	1.94%	3.24%	3.42%	4.59%	8.49%	11.26%	14.56%	0.052
Volatile Organic Compounds (VOCs)	NA - M16	1.2	tonnes		tonnes	14.38%	13.29%	11.37%	7.69%	5.79%	1.94%	3.24%	3.42%	4.59%	8.49%	11.26%	14.56%	1.2
ANNUAL STACK REPORTING																		
Is there Equipment with Stack => 50m above grade?															Click Here to Return to Start Page			
CONTAMINANT NAME	CAS#	ANNUAL STACK (≥ 50 m) AIR RELEASES FROM	UNITS	ANNUAL STACK (≥ 50 m) AIR RELEASES FROM ALL OTHER SOURCES EXHAUSTED THROUGH	UNITS	TOTAL ANNUAL STACK	UNITS	STACK AIR RELEASE	UNITS	PERCENT OF STACK AIR RELEASE	REQUIREMENT TO REPORT STACK (≥ 50 m) AIR RELEASES							

RELEASE

THRESHOLD

0.25

tonnes tonnes

RELEASE

THRESHOLD

AND

PHYSICAL STACK

PARAMETERS

No

No

No

No

No

No

(≥ 50 m)

AIR

RELEASES

tonnes

tonnes tonnes

tonnes

tonnes

tonnes tonnes

tonnes tonnes tonnes

tonnes

COMBUSTION EQUIPMENT

SELECTED

630-08-0 11104-93-1 NA - M09

NA - M10

NA - M08 NA - M16

Carbon Monoxide

Total Particulate Matter
Volatile Organic Compounds (VOCs)

THE SAME ≥ 50 m

STACK AS THAT FOR

THE COMBUSTION

EQUIPMENT SELECTED