

<b>Location</b>	<b>TONS OF POLLUTANT</b>								
	<b>NO x</b>	<b>SO x</b>	<b>CO</b>	<b>PM</b>	<b>O3</b>	<b>Pb</b>	<b>HAPs</b>	<b>ODCs</b>	<b>Other emissions</b>
Indiana University Biotechnology Research and Training Center Boiler Units: L3B-01 and L3B-02	1.14	0.007	0.95	0.09	0	0.0000056	0	0	0.072
Small Diesel Emergency Generators	1.4	0.1	0.3	0.1	0	0	0	0	0.97
Large Emergency Generators (>600 Hp) (26 Hours of Operation per Year)	9.73	0.69	2.1	0.64	0	0	0	0	6.78
Natural Gas Emergency Generators	0.019	0.00006	0.0035	0.00039	0	0	0	0	0.0012
Incineration Equipment	0.0095	0.0098	0.0009	1.88	0	0	0	0	0
<b>TOTALS</b>	<b>12.2985</b>	<b>0.80686</b>	<b>3.3544</b>	<b>2.71039</b>	<b>0</b>	<b>0.0000056</b>	<b>0</b>	<b>0</b>	<b>7.8232</b>

**ACTUAL EMISSION SUMMARY**  
**INDIANA UNIVERSITY – PURDUE UNIVERSTIY INDIANAPOLIS**  
**2019 Summary**

**Indiana University Biotechnology Research and Training Center Boiler Units: L3B-01 and L3B-02**

<b>10<sup>6</sup> scf Natural Gas</b>	<b>Pollutant</b>	<b>Emission Factor</b>	<b>Pounds of Pollutant</b>	<b>Tons of Pollutant</b>
22.7	NO <sub>x</sub>	100	2270	1.14
22.7	CO	84	1906.8	0.95
22.7	PM	7.6	172.5	0.09
22.7	SO <sub>2</sub>	0.6	13.62	6.8 x 10 <sup>-3</sup>
22.7	VOC	5.5	124.9	6.25 x 10 <sup>-2</sup>
22.7	Pb	0.0005	1.3 x 10 <sup>-2</sup>	5.7 x 10 <sup>-6</sup>

**Small Diesel Emergency Generators (<600 Hp)**

<b>Generator</b>	<b>Rated Hp</b>
ESG-01	536.4
IHG-01	469.5
TKG-01	449
HO/IPG-01	402.3
XRG-01	402.3
WD-PCG-01	308.4
PEG-01	258.2
WD-HSG-01	258.2
WD-LVG-01	234.7
BAG-01	107.3
XLG-01	167.6
<b>Total Hp</b>	<b>3613.9</b>

<b>Total Rate HP</b>	<b>Pollutant</b>	<b>Hours of Operation</b>	<b>Emission Factor</b>	<b>Pounds of Pollutant</b>	<b>Tons of Pollutant</b>
3613.9	NO <sub>x</sub>	25	0.031	2800.8	1.4
3613.9	CO	25	0.00668	603.5	0.30
3613.9	PM	25	0.00205	185.2	0.1
3613.9	SO <sub>2</sub>	25	0.00220	198.8	0.1
3613.9	VOC	25	0.02159	1950.6	0.98

**Large Emergency Generators (>600 Hp) (25 Hours of Operation per Year)**

Generator	Rated Hp
WD-RVG-01	2447.3
WD-RVG-02	2447.3
ITG-01	1676.3
R3G-01	1676.3
R3G-02	1676.3
NBG-01	1341
ULG-01	1341
R2G-01	1206.9
R4G-01	1206.9
MSG-01	1206.9
MSG-02	1206.9
HSG-01	1180
IBG-01	1072.8
HSG-01	1072.8
DSG-01	1005.8
GKG-01	890
L3G-01	1005.8
ELG-01	804.6
CEG-01	637
<b>Total Hp</b>	<b>25,101.9</b>

Total Rate HP	Pollutant	Hours of Operation	Emission Factor	Pounds of Pollutant	Tons of Pollutant
25,101.9	NO <sub>x</sub>	25	0.031	19454.0	9.76
25,101.9	CO	25	0.00668	4192.0	2.1
25,101.9	PM	25	0.00205	1286.5	0.64
25,101.9	SO <sub>2</sub>	25	0.00220	1380.6	0.69
25,101.9	VOC	25	0.02159	13548.8	6.77

### Natural Gas Emergency Generators

Generator	Rated Hp
XDG-01	258.2
S2G-01	33.5
Total Hp	301.7

(1hp = 2544 BTU/hr. 301.7 hp x 2544 BTU/hr = 767,524.8 BTU/hr x 25 hr = 19,225,813 MMBtu = 19.23 MMBtu)

Total Rate HP	Pollutant	Hours of Operation	Emission Factor	Pounds of Pollutant	Tons of Pollutant
301.7	NO <sub>x</sub>	25	1.94	37.3	0.02
301.7	CO	25	0.353	6.8	3.4 x 10 <sup>-3</sup>
301.7	PM	25	0.0384	0.74	3.7 x 10 <sup>-4</sup>
301.7	SO <sub>2</sub>	25	0.000588	1.1 x 10 <sup>-2</sup>	5.7 x 10 <sup>-5</sup>
301.7	VOC	25	0.120	2.3	1.2 x 10 <sup>-3</sup>

### Incineration Equipment

#### CS4I-01

Hours of Operation: 8 Hours/day, 5 days per year = 40 Hours

Hours of Operation	Pollutant	Emission Rate (Pounds/Hour)	Pounds of Pollutant	Tons of Pollutant
40	NO <sub>x</sub>	0.474	19.0	9.45 x 10 <sup>-3</sup>
40	CO	0.04485	1.8	9.0 x 10 <sup>-4</sup>
40	PM	0.5145	20.58	1.0 x 10 <sup>-2</sup>
40	SO <sub>2</sub>	0.4875	19.5	9.8 x 10 <sup>-3</sup>

### Campus Emission Summary (In tons)

Emission Source	Pollutant - NO <sub>x</sub>	Pollutant - CO	Pollutant - PM	Pollutant – SO <sub>2</sub>	Pollutant - VOC
L3 Boilers	1.14	0.95	1.01	0.0079	0.72
Small Generators	1.4	0.30	0.1	0.10	0.98
Large Generators	9.76	2.1	0.64	0.69	6.77
Natural Gas Generators	0.019	0.0034	0.00037	0.000057	0.0012
CS4 Incinerator	0.0095	0.0009	0.01	0.0098	-----
Totals	12.33	3.35	1.76	0.81	7.82