0115

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER Monitoring Reporting Requirements Not Met for <u>Timberline-CV PSD</u> <u>WV3304711</u>

Timberline-CV PSD WV3304711

Our water system violated drinking water monitoring requirements. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation. We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During periods listed in the table below, we did not monitor or test as required and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

At this time, there is nothing you need to do.

The table below lists the required monitoring and the compliance period.

Monitoring Violation	Year-Fed	Monitoring	Compliance
_	Report #	Frequency	Period
03, MONITORING, ROUTINE MAJOR			
Arsenic Total Results Not Submitted	2022-11927	Annually	YR 2021

What happened? What is being done? (Describe corrective action)

The Arsenic sample for 2021 was not taken so there were no test results to be submitted. The operator was recently hired at the time of this violation and did not have a complete understanding of the drinking water sampling plan. It is now standard practice to incorporate the drinking water sampling plan into a calendar that further breaks down which samples that are to be taken into detailed biweekly checklists so no water samples can be mistakenly overlooked.

For more information, please contact Wesley Knotts at (304) 676-0317 or knottswesley@gmail.com.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Prepared: January 03, 2025

Date Distributed: January 10, 2025