

# Bureau of Fire Safety – Borough of Rutherford

176 Park Avenue, Rutherford, NJ, 07070, 201-460-3011

## Mobile Cookline Inspection Checklist

The Fire Safety Permit applicant shall complete the following mobile cookline inspection checklist as part of the Fire Safety Permit Application. This checklist is required to be submitted 5 days prior to the event.

<b>Business Name:</b>
<b>Owner/Agent Name:</b>
<b>Owner/Agent Phone #:</b>
<b>Owner/Agent Email Address:</b>
<b>Owner/Agent Address</b>
<b>Event Date(s):</b>
<b>Event Location:</b>
<b>Owner/Agent Signature:</b>

#	Item	YES / NO	Comments
1.	Fire protection system inspection, test and maintenance performed within the past six months of the date of the event?		
2.	Provide a copy of the latest inspection, test and maintenance report from your fire protection contractor to the Bureau of Fire Safety, Borough of Rutherford?		
3.	Is a Class "K" Fire Extinguisher provided? The fire extinguisher shall display a current inspection tag, within 12 months of the date of the event.		
4.	The fire suppression system control head is in the set or ready position? Provide a photo of the control head?		
5.	Provide photos of the cookline detailing the position of the suppression system nozzles?		
6.	Name of Fire Protection System Contractor:		
7.	Date of last inspection, testing and maintenance on fire suppression system:		

Attached the photos above to your email when you return this checklist to: [firesafety@rutherfordboronj.com](mailto:firesafety@rutherfordboronj.com).

You may contact the Bureau of Fire Safety at 201-460-3011 if you have any questions.

Bureau of Fire Safety Use Only	
Date Inspected:	Inspected By:
Approved Y / N?	If No Why:
Comments:	