



試驗報告

報告編號: KV-24-10651

數: 1 OF 1

報告發行日期: 113 年 12 月 03 日

成大昶閎科技股份有限公司

產品名稱: 樂土單組份彈性水泥

產品顏色: 淺灰

供應廠商:成大昶閎科技股份有限公司 送驗廠商:成大昶閎科技股份有限公司

收件日期: 113年 11月 12日

試驗日期: 113年 11月 12日~113年 12月 03日

註:1.以上資料(會驗廠商、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明,此報告結果僅適用於收取之試驗件 未經本公司事先書面同意,此報告不可部分複製

試驗結果:

試驗項目			試驗方法	試驗結果
拉伸性能	抗拉強度(kgf/cm²)	試驗溫度 23 ℃	CNS 8644: 2014	22
	斷裂伸長率(%)	試驗溫度 23 ℃		470
撕裂性能 撕裂		撕裂強度(kgf/cm)	(丙烯酸酯橡膠系) —	14
附著強度(kgf/cm²)			CNS 10757: 1995	38.8

- 註:1.#附著強度試驗樣品為單液型;其餘試驗試體由委託單位製作提供。
 - 2.本試驗報告拉伸性能、撕裂性能試驗為本實驗室 TAF 認證範圍,其餘則非。
 - 3. 樣品描述: 防水材料。
 - 4.本實驗室執行試驗之地點同實驗室地址。

---- 000 -----

本報告若有提供規範值,該規範值僅供參考,合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com.tw/Terms-and-Conditions and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com.tw/Terms-and-Conditions. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. WE1901824

No.61, Kai Fa Rd., Nanzih District, Kaohsiung City 811637, Taiwan /811637 高雄市楠梓區開發路61號 t (886-7) 301-2121 f (886-7) 301-1165 www.sgs.com.tw SGS Taiwan Ltd.

rita-tw chen