

## TERMITE PROTECTION SPECIFICATION

---

### WHOLE OF PROPERTY PROTECTION

The building must be protected in accord with the requirements of the Australian Standard *AS 3660 Termite management, Part 1 New building work (AS 3660.1)*.

All critical areas of termite entry including the external building perimeter, construction joints and slab penetrations shall be protected by a termite management system such as **TRITHOR™ Termite Protection**; that meets the requirements of the Building Code of Australia (BCA); when installed in conjunction with a concrete slab built to AS2870.

The System must contain the pyrethroid deltamethrin at a concentration no greater than 1 g per square metre. The System installation is to conform to the System manufacturer's installation guidelines who shall provide evidence of compliance with the Building Code of Australia (BCA). The system must be CodeMark Accredited.

*A minimum Manufacturers' Warranty of fifty (50) years for the building shall be provided, renewable on a year by year basis, by annual inspection, by the System installation organisation. The warranty shall provide termite damage replacement should a System breach occur.*

A Durable Notice in accord with the specifications of Clause A1 of AS 3660.1 shall be provided and fixed as per BCA requirements. The Durable Notice shall be permanently fixed to the building in a prominent location such as a meter box plus, a kitchen cupboard, or similar, with the following advice provided:

- The method of protection e.g. TRITHOR Termite Protection.
- Date of installation.
- The life expectancy of the System, minimum of fifty (50) years.
- The installer's or manufacturer's recommendations for the scope and frequency of future inspections for termite activity – at least once every 12 months.

### AUSTRALIAN STANDARD

To be installed in compliance with AS 3660.1.

### INSPECTIONS

Give sufficient notice so that inspections may be made of the completed Termite Management System.

### MATERIALS AND COMPONENTS

Proprietary item: **TRITHOR Termite Protection**

200 g per square metre blanket with a loading of 1 g per square metre of deltamethrin, sandwiched between a 200 µ LDPE plastic membrane, colour blue; and a 50 µ LDPE plastic membrane, colour yellow.

### COMPLETION

Certification in accord with AS3660.1 to be provided after installation has been completed, i.e. a **Certificate of Compliance, a Site Installation Report, Warranty Documentation and a Termite Information Sheet.**

### WARRANTY

A written fifty (50) year, whole of structure, Termite Damage Warranty must apply, with a requirement for annual inspections.