



BUILDING SEWER PIPE
SHALL CONFORM TO THE STANDARD LISTED BELOW.

MATERIAL	STANDARD
Cast-Iron pipe	ASTM A74; CISPI 301; ASTM A888
Poly-Vinyl Chloride (PVC) SDR-26	ASTM D2566, ASTM F477, ASTM F789

- NOTES:**
- CONSTRUCTION SHALL COMPLY WITH THE PENNSYLVANIA UNIFORM CONSTRUCTION CODE (U.C.C.) AND THIS DRAWING, AS A MINIMUM.
 - CLEANOUTS SHALL BE INSTALLED NOT MORE THAN 50' APART IN HORIZONTAL DRAINAGE LINES OF 4" DIA. OR LESS, NOT MORE THAN 100' APART FOR LARGER DIA. PIPES, AT ALL CHANGES OF DIRECTION, AND AT THE PROPERTY LINE OR CURB LINE, AS SHOWN IN THE ABOVE DETAIL.
 - ON-LOT SEWAGE DISPOSAL SYSTEM SHALL BE ABANDONED, IF APPLICABLE.
 - VENTS WILL NOT BE PERMITTED IN PAVED AREAS.
 - CLEANOUTS, IF PLACED WITHIN PAVED AREAS, SHALL BE PROTECTED FROM VEHICULAR DAMAGE BY LOCATING IN CAST IRON OR DUCTILE IRON FRAME AND COVER MARKED "SEWER" (SEE DETAIL SA-002).
 - PROVIDE STONE BEDDING AS SHOWN ABOVE.
 - PROPERTY OWNER SHALL BE RESPONSIBLE FOR SEALING THE LATERAL PENETRATION THROUGH THE BUILDING. THE AUTHORITY SHALL NOT BE RESPONSIBLE FOR ANY GROUND WATER ENTERING INTO THE BUILDING.

TYPICAL OUTSIDE SERVICE CONNECTION
NOT TO SCALE

N:\ENVENG\Municipal Documents\5774-Pine Grove JTA\Developer Spec\04577404-Details.dwg

SPECIFICATIONS FOR
PINE GROVE JOINT TREATMENT AUTHORITY
SCHUYLKILL COUNTY, PA

RETTEW ASSOCIATES, INC.
3020 Columbia Ave., Lancaster, PA 17603
TEL (717) 394-3721 • FAX (717) 394-1063

DRAWN BY: CH
DATE: APRIL 2011
SCALE: NOT TO SCALE
DWG. NO. 04-05774-004