

120 West Verbena Avenue
Foley, Alabama 36535
(251) 943-1266
Fax (251) 943-7432
www.cityoffoley.org

Food Vendor Requirements

These requirements apply to single vendor, freestanding booths. All food vendors are subject to inspection prior to an event. Failure to comply with the following regulations may result in closure of the location.

Concession Trailers


A restaurant suppression system check is required (certification must be current within 6 months prior). If deep frying is conducted, you must have a K-Type fire extinguisher to accompany your kitchen system. For all other cooking you must have a 2A-10B:C classification fire extinguisher (5lb.).

Flame Retardant Requirements

The sidewalls, drops and tops of tents and canopies shall be of flame resistant material or treated with a flame retardant in an approved manner. A tag shall be permanently fixed to the structure that proves that the tent is compliant.

Portable Fire Extinguishers

A portable fire extinguisher shall be provided for each food booth. The minimum size for the extinguisher is 2A 10B: C (5 lbs.). If a Deep Fat Fryer is being used, a K TYPE extinguisher shall also be provided. Extinguishers shall have a current inspection tag (certification must be current within 12 months prior). The extinguishers shall be securely mounted in an accessible and visible location, between 3 and 5 feet above the ground.



120 West Verbena Avenue
Foley, Alabama 36535
(251) 943-1266
Fax (251) 943-7432
www.cityoffoley.org

Gas Stoves

All gas stoves, grills and burners shall be listed by either Underwriters Laboratories (UL) or the American Gas Association (AGA).

Portable LP Gas Cylinders

Fuel tanks (LPG) shall be stored outside of the structure. The tanks shall also be located away from public access. The size of the tank shall be limited to 7 gallons, unless otherwise approved. Fuel tanks shall be secured from falling.

Smoking


Smoking is not allowed at any time within the food booth, or within 25 feet of any fuel source. (No Smoking signs shall be posted within each food booth.)

Generators

Generators shall be located a minimum of 20 feet from tents or canopies. They shall also be isolated from contact with the public by approved means. The refueling of hot generators is not allowed.

Flammable and Combustible Liquids

Flammable and Combustible Liquids shall not be stored within or adjacent to the structure.



120 West Verbena Avenue
Foley, Alabama 36535
(251) 943-1266
Fax (251) 943-7432
www.cityoffoley.org

A copy of these regulations shall be posted in the structure and signed by the vendor. By signing this form the vendor agrees to comply with these regulations. The signed copy will be available on request for review by the Foley Fire Department. Should you have any questions contact Nelson Bauer at the Foley Fire Department, 251-971-6028.

Vendor's signature and date of event