

# Specifications For FB-Series Bag-In/Bag-Out Housing

The housing shall be P&G FB-series bag-in/bag-out, fluid seal housing and shall be manufactured from 14 Ga. & 11 Ga. T-304 stainless steel (unpainted). The housing shall be adequately reinforced to withstand a negative or positive pressure of 10" water gage. The housing shall be side-servicing for filter installation and change-out. Housing design and filter arrangement shall allow air to enter and exit housings without changing direction. The housing shall accommodate standard size fluid seal filters which require a knife edge flange at the housing seal surface. Seal is effected when filter gel track is pushed onto the knife-edge flange.

## Welding

All "pressure retaining" weld joints and seams shall be continuously welded; weld joints and seams requiring only intermittent welds by design shall not be continuously welded. As a minimum, all weld joints and seams shall be wire brushed and/or buffed to remove heat discoloration, all burrs, and sharp edges. All weld joints and seams that are a portion of any gasket setting surface (i.e., duct connecting flanges) shall be ground smooth and flush with adjacent base metals. All welding procedures, welders, and welder operators shall be qualified in accordance with ASME Boiler and Pressure Vessel Code, Section IX. All production welds shall be visually inspected per the workmanship acceptance criteria described in sections 5 & 6 of ANSI/AWS D9.1-1990, "Specification for Welding of Sheet Metal".

## Bagging Ring

The housing shall have a bagging ring flange around each filter access port, that is sealed by a gasketed filter access door. The filter access door gasket shall be neoprene and shall be manually replaceable. The bagging ring flange shall have two (2) continuous formed raised ridges to secure the PVC change-out bag. The bagging ring flange is hemmed on the outer edge to prevent the change-out bag from tearing. One (1) PVC change-out bag shall be furnished with each filter access port. Change-out bags shall be 8 mil. thick with a yellow translucent, non-sticking, matte textured finish and have a 1/4" dia. elastic shock cord hemmed into the opening of the bag so when stretched around the bagging ring flange, it is a secure fit. Bag shall include three (3) glove ports built into the bag to assist in filter change-out. One (1) security strap shall be furnished per filter access port, to prevent the bag from sliding off the bagging ring flange during the filter change process. All change-out operations shall be within the bag.

## Hardware

All hardware on the housing and mechanical components of the filter sealing mechanism are 300 series stainless steel except for the access door knobs which are cast aluminum (to prevent galling of threads).

## Locking Handle

The filter sealing mechanism shall be replaceable and shall be operated by a locking handle that is operated through the change-out bag. The sealing mechanism is designed to exert an equal force to the top and bottom edge of each filter when engaging and disengaging the filter on the knife edge flange.

## Removal Rod

Multi-wide housing shall be equipped with a filter removal rod to pull the filters to the change-out position. The removal rod shall operate from inside the filter change out bag.

## Quality

Quality assurance and factory testing: The filter housing shall be manufactured under a quality assurance program that addresses the requirements of ANSI/ASME NQA-1, "Quality Assurance Program Requirements for Nuclear Facilities". Housing shall be tested for filter fit, operation of the filter clamping mechanism, knife edge alignment, and leak tightness before leaving the factory. Both the filter sealing surface and the complete assembly pressure boundary shall be leak tested by the "pressure decay method", in accordance with ANSI/ASME N510-1989 (reaffirmed in 1995), "Testing of Nuclear Air-Cleaning Systems", paragraphs 6 & 7 and have a maximum leak rate of 0.0005 CFM per cubic foot of housing volume at 10" water gage. Test duration shall be 5 minutes with pressure readings recorded at 1 minute intervals.

# P&G MANUFACTURING

WASHINGTON N.C. 27889  
 PHONE NO.: 252-946-9110  
 FAX NO.: 252-946-4823



DRAWN BY: HJH		TITLE FLUID SEAL BAG IN/BAG OUT SPECIFICATIONS		
DATE: 8/11/2016		APPR. BY: RBD		
APPROVED BY: RBD		CONTROL NO.		DWG SCALE: NTS
DATE: 8/11/2016	DRAWING NO.:	SHEET	OF	REV.
	FB-SPEC	1	1	-

REV.	DRAWN BY DATE	DESCRIPTION:	APPR. BY DATE
THE DEVICE DEPICTED AND DESCRIBED HEREON EMBODIES PROPRIETARY INFORMATION OWNED BY P&G MANUFACTURING INC. ALL DESIGN, MANUFACTURING, REPRODUCTION, SALES, AND PATENT RIGHTS REGARDING THIS DEVICE OR DRAWING ARE RESERVED EXCEPT WHERE EXPLICIT RIGHT IS GRANTED IN WRITING.		UNLESS OTHERWISE SPECIFIED • ALL DIMENSIONS ARE IN INCHES • TOLERANCES ARE:	FRACTION: $\pm 1/8"$ DECIMAL: $\pm 0.005$ ANGULAR: $\pm 1^\circ$

TEXT HEIGHT: DIM/SCALE: