

Slip Check to AS 4586:2013 Timberlink Green Microline LOSP treated timber

This Report Replaces Report Number M0235c

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

31 October 2016

Test Report No. M0235.1c

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

This Report Replaces Report Number M0235c

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.


Requested by: Timberlink Australia
Client Address: 331 Old Bell Bay Road
Bell Bay TAS 7253
Product Manufacturer: Timberlink Australia
Product Description: Timberlink Green Microline LOSP treated timber

Test conducted according to: AS 4586:2013 Appendix A
Modification: Tested perpendicular to grain at request of client for use as stair nosings
Location: Slip Check Pty Ltd Test Facilities, Melbourne VIC 3000
Conducted by: Nasser Cura

Date: 21 October 2016 Temperature: 20°C
Sample: Unfixed Cleaning: None
Rubber slider used: Slider 96 Conditioned: Grade P 400 paper dry followed by wet lapping film
Slope of specimen: Tested on a flat level surface
Direction of Test: Approximately 90° to profile and grain

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	45	47	47	47	46

Reported SRV of Sample:	46
Class:	P4



Martin Daniel
Materials Scientist