



LABORATORY TEST RESULTS

FILE NUMBER: 52137-2015-2857

COMPANY: XP Lab Inc.

TEST DESCRIPTION	DETECTION LIMIT	UNITS	TEST METHOD
Pour Point	-60	°C	ASTM D-97

SAMPLE NO.	SAMPLE IDENTIFICATION	RESULTS	DATE ANALYZED	TECH
1-336	<p style="text-align: center;"><b>XP3 Baseline Diesel</b>  <b>Pure Diesel</b>  <b>Received on August 31, 2015</b></p>	<b>-27</b>	14-Sep-15	JC
2-465	<p style="text-align: center;"><b>XP3 Extreme Winter Additive</b>  <b>Pure Additive</b>  <b>Received on September 4, 2015</b></p>	<b>-54</b>	14-Sep-15	JC
3-001	<p style="text-align: center;"><b>XP3 Extreme Winter Additive with Diesel</b>  <b>1:1000 volume ratio</b>  <b>Blend on September 04, 2015</b></p>	<b>-57</b>	14-Sep-15	JC
4-002	<p style="text-align: center;"><b>XP3 Extreme Winter Additive with Diesel</b>  <b>1:2000 volume ratio</b>  <b>Blend on September 04, 2015</b></p>	<b>-54</b>	14-Sep-15	JC
5-003	<p style="text-align: center;"><b>XP3 Extreme Winter Additive with Diesel</b>  <b>1:4000 volume ratio</b>  <b>Blend on September 04, 2015</b></p>	<b>-51</b>	14-Sep-15	JC

CORE LABORATORIES  
2810 - 12th St. N.E.  
CALGARY, ALBERTA T2E 7P7