

Attention: Sheila McConnell, Director
Mine Safety and Health Administration
Office of Standards, Regulations, and Variances
201 12th Street South, Suite 4E401
Arlington, Virginia 22202

ID: LFG-2018-0028

June 20th, 2018

Re: Docket Number, MSHA-2018-0021
In Re: Greenbrier Minerals, LLC's petition
In Re: Solvay Chemicals, Inc's petition

Dear Sheila McConnell,

I am sending you this communication in regard and pertaining to a notice of a summary petition submitted to the Mine Safety and Health Administration (MSHA) by Greenbrier Minerals, LLC and by Solvay Chemicals, Inc. Therefore, please consider this communication to you as a comment in which is in regard and pertaining to a notice of a summary petition that was submitted to the Mine Safety and Health Administration (MNSA) as Docket Number, MSHA-2018-0021.

In Re: Greenbrier Minerals, LLC's petition:

It is to my knowledge and understanding that Greenbrier Minerals, LLC is requesting modification to the installation of main mine fans existing standard, in which would allow the Powellton No. 1 Mine to feed power from a new, isolated surface substation by borehole feed, to replenish power for future mine advancement and to provide power for the No. 3 Coal Branch fan installation. This proposed request would affect the installation of main mine fans standard, in which is known as 30 CFR 75.310(b)(1). Specifically, Greenbrier Minerals, LLC as the petitioner has petitioned the Mine Safety and Health Administration has stated the following:

1. Feeding of power will be from an isolated surface substation dedicated only to the borehole feed. This feed circuit will be a three-phase, 12.47 KV High-Voltage Circuit that is run on open wire and poles with neutral and pilot, with the pilot wire mounted on separate insulators the entire length. The system circuit breaker will be controlled by an SEL-501-2 Digital Fault Relay, and wire and cable grounds will be monitored by an MCI 22701 impedance monitor.
2. A surface Gang Operated Air Break (GOAB) switch is located at the top of the borehole with Lightning Arrestors on each phase. The Lightning Arrestors will be grounded by attaching a 15 KV rated cable that will be placed at a minimum of 25 feet away from the borehole structure or station ground field.
3. The borehole cable will be a Mine Power Feeder (MPF) constructed cable, 15 KV, 4/0-3 Conductor SHD (Shield) GGC. The cable will be hung by wire messenger and supported at the top rim and every subsequent 100 feet span. All messenger and apparatus at the

borehole location will be grounded to the station ground field in accordance with current MSHA, West Virginia Office of Miners HS&T, and applicable NEC Code regulations.

4. At the exit of the bottom of the borehole, the cable will enter a Mining Controls, Dual Vacuum Breaker Switch House (A). The switch house features AEEI A8200, diode terminated, ground monitors and SEL-751A Digital Fault Relays. It will also feature three phase Tavrida Electric Vacuum Breakers rated 800A, 15KV, 20kAIC.
5. One circuit from the Dual Vacuum Switch House (A) will be dedicated to feed into a second Dual Vacuum Switch House (B) which will send refreshed power to petitioner's Section 2 and Section 3 Continuous Miner Sections. This switch house features AEEI A8200, diode terminated, ground monitors and SEL-501-2 Digital Fault Relays. It will also feature three phase MCI Electric Vacuum Breakers rated 600A, 15KV, 20kAIC.
6. The other circuit from the Dual Vacuum Switch House (A) will be dedicated to feed only the fan circuit which is approximately 12,000 feet to the portal. The supplying cable will be a Mine Power Feeder (MPF) constructed cable, 15 KV, 4/0-3 Conductor SHD (Shield) GGC. The cable will be terminated at a Pole Mounted, GOAB Switch with Lightning Arrestors. The lightning arrestors will be grounded by attaching a 15 KV rated cable that will be placed at a minimum of 25 feet away from all station grounds. The pilot and ground will be terminated in an enclosure with an "Emergency Stop" switch located near the fan controls.
7. Power will enter on the primary side of a set of three 167KVA (12.4KV-Delta X 480V-WYE) pole mounted transformer cans. These cans are fuse protected and have lightning arrestors for each phase. These lightning arrestors will be grounded by attaching a 15 KV rated cable that will be placed at a minimum of 25 feet away from station grounds. The secondary side of the transformers (480V AC) will feed into a (Fully Automated Transfer Switch) and then to the Fan VFD Motor Starter, that will power the 250 horsepower fan motor.
8. The alternate power source is a Caterpillar Generator XQ300-C9 (300 KW) feeding the fully automatic transfer switch 480V AC power anytime there is a power interruption. The generator will start, the transfer switch will switch to generator supplied power, and the whole process takes approximately 39 seconds for the fan to be running at the set capacity. The generator has a fuel tank capacity of 430 gallons and the fan has a fuel consumption rate of 18.6 gallons per hour. Therefore, the fan can run from the generator for approximately 23 hours from the onboard tank. There is also an additional supply tank to fill the generator tank that holds 1,000 gallons of fuel, providing an additional run time of 53 hours plus. This will allow time to troubleshoot, repair, test, and reenergize the High-Voltage Feeder Circuit or have additional fuel delivered to the site.
9. All normal backup notification systems will be installed including radio remote warning signals that the fan is not running, fiber-optic communication, and security cameras monitoring the site.
10. They operate the affected underground coal mine which additional power feeds are required to replenish power to two working sections and supply power to the #3 Coal Branch Fan Installation.
11. The #3 Coal Branch Fan will be installed to meet Ventilation Plan requirements as set forth in petitioner's Ventilation Plan.
12. There is no Three-Phase Utility Power of any voltage available within 9.5 miles.

13. The borehole location is very remote, approximately 2.2 miles from the substation location, thus would be considered a security risk for damage should the substation be placed there. Mine personnel can be at the borehole location in approximately 45 minutes vs. 5 minutes travel to the current location that is located behind the Preparation Plant of the Main Substation.
14. Mining is being conducted by another mining company which intersects with Greenbrier Minerals property line. Petitioner states that it could get right of way to build across the other company property line but in subsequent years would have to move two sections of power line, and our substation would be in a blasting area that could lead to damage from flying debris, air-shock, and ground vibrations.
15. They request that the Powellton #1 Mine be allowed to feed both mine power systems and petitioner's #3 Coal Branch Fan Installation on one system where such occurrences of a fault trip on the main feed would be kept to a minimum by utilizing the dual series vacuum breaker configuration. In those rare instances where the dual vacuum breaker configuration should fail, petitioner has included a fully automatic system with a transfer switch and generator that will restore power to the #3 Coal Branch Fan in less than one minute.
16. The proposed modification would not only ensure operable ventilation, it would also ensure through weekly functional testing that the alternate power supply would function as intended and adequately maintain mine ventilation. The petitioner asserts that the proposed alternative method will achieve the purpose of the existing standard and will always guarantee no less than the same measure of protection afforded by the standard.

I believe that the best way for the Mine Safety and Health Administration to help ensure that the Code of Federal Regulations is being in compliance with, and when any entity tries to request a modification to an already established Code of Federal Regulations, is to have officials with the Mine Safety and Health Administration, conduct an onsite inspection, to help ensure that the modification request that was requested by Greenbrier Minerals, LLC is proper and that it is necessary, and that Greenbrier Minerals, LLC has no way as to being in compliance with the already established Code of Federal Regulations, without the modification request. The safety and the security of employees of Greenbrier Minerals, LLC should be considered and should be ensured to be protected by the Mine Safety and Health Administration.


In Re: Solvay Chemicals, Inc's petition:

It is to my knowledge and understanding that Solvay Chemicals, Inc. is requesting a modification to the existing standard to permit the use of alternative controls in lieu of the installation of control doors. The affected Code of Federal Regulation per Solvay Chemicals, Inc's petition, would be 30 CFR 57.4760(a) as to Shaft mines. It should be noted that Solvay Chemicals, Inc. has stated to the Mine and Safety Health Administration that the fire control doors located near the #3 shaft in this Class III Gassy Mine presents a diminution of safety to the miners because the installation of control doors or the reversal of mechanical ventilation would affect the main air currents and splits, thus adversely impacting the ventilation system's ability to render and dilute concentrations of toxic gases or methane gas. Additionally, the installation of control doors or the reversal of mechanical ventilation can only be achieved by shutting down the mine's main exhaust fans. Due to the expanse of the mine, evacuation of all personnel underground to the surface in ten minutes or less is not an alternative means of compliance with the standard. It is to my knowledge and understand that Solvay Chemicals, Inc. seeks to

remove the fire control doors and requests a modification of the existing standard to permit the use of alternative controls in lieu of the installation of control doors. So, Solvay Chemicals, Inc. is requesting:

1. A modification of 30 CFR 57.4760(a), that authorizes the petitioner to establish an alternative method in lieu of the mandatory safety standard. The petitioner considers the following alternatives to the installation of control doors as acceptable means to control the spread of fire, smoke, and toxic gases underground in the event of a fire specific to the petitioner's mine: (a) Solvay Chemicals, Inc. currently has four shafts constructed of non-combustible materials. All four existing shafts will be provided with a means of hoisting mine personnel. At all times, two properly maintained escapeways to the surface from the lowest levels will be maintained. (b) Conveyor belting used underground will be 2G compliant or meet the equivalent flame spread rating. The petitioner asserts that application of the existing standard will result in a diminution of safety to the miners and that the proposed alternative method will provide the same measure of protection afforded by the standard.

I believe that the best way for the Mine Safety and Health Administration to help ensure that the Code of Federal Regulations is being in compliance with, and when any entity tries to request a modification to an already established Code of Federal Regulations, is to have officials with the Mine Safety and Health Administration, conduct an onsite inspection, to help ensure that the modification request that was requested by Solvay Chemicals, Inc. is proper and that it is necessary, and that Solvay Chemicals, Inc. has no way as to being in compliance with the already established Code of Federal Regulations, without the modification request. The safety and the security of employees of Solvay Chemicals, Inc. should be considered and should be ensured to be protected by the Mine Safety and Health Administration.


Respectfully,

Isaiah X. Smith¹

¹ www.isaiahxsmith.com