

A personal membership group of the **American Hospital Association** 

# Q1 ASHE Advocacy Liaison Webinar 21 March 2018





# Agenda

- NFPA Update
- WMTS Update
- ICC Cycle A Update
- ASHRAE Public Review Opportunities
- Local Advocacy Reports





# NFPA Update

## NFPA 3000

- Standard for Preparedness and Response to Active Shooter and/or Hostile Events
  - Being Expedited
  - Provisional Standard



## NFPA 101 & 99

- Next Edition 2021 in Cycle
- Currently Open for Public Input
  - Closing Date: 27 June 2018
  - First Draft Report to be posted 27 February 2019
- Call for Volunteers to Review Open
  - Apply online at My ASHE
    - Under the Volunteer Tab
    - Volunteer Opportunities
    - ASHE NFPA 101 Life Safety Code Review Group



#### ASHE NFPA 101 LIFE SAFETY CODE REVIEW GROUP

< RETURN TO LIST

Starts: 03-06-2018

Location: Online Opportunity

#### **APPLY TODAY!**



#### DESCRIPTION:

The Life Safety Code is the most widely used source for strategies to protect people based on building construction, protection, and occupancy features that minimize the effects of fire and related hazards. Unique in the field, it is the only document that covers life safety in both new and existing structures. This opportunity will require review of the 2018 edition of NFPA 101 and submission of comments, concerns, corrections or clarifications that are needed for the next edition so that ASHE can advocate for the changes.

#### CONTACT:

Sharon Autrey
Manager, Administration & Governance
American Society for Healthcare Engineering

<u>sautrey@aha.org</u>

Sign-Up Deadline March 16, 2018

Extended until Friday 23 March

Opportunity Start Date: March 19, 2018 Opportunity End Date: May 1, 2018

#### To Apply:

In order to participate, you must complete this <u>conflict of interest and</u> <u>nondisclosure form</u>. Please complete this form and then upload it as part of your application when applying for this opportunity at the link above.

#### **VOLUNTEERS NEEDED:**

10 (10 open slots)

#### EXPERIENCE REQUIRED:

All levels of experience are welcome

## NFPA 101 & 99

- Survey process (See-it/Cite-it)
  - Causing concerns with interpretation/applicability
  - Example of monthly visual inspection of sprinkler heads documentation
  - Can no longer happen through routine maintenance and operational duties
- NFPA Conference June 11-14 in Las Vegas, NV



# WMTS Update


# WMTS Update


- Medical telemetry operating in the following bandwidths must be registered:
  - 608 614 MHz
  - 1395 1400 MHz
  - 1427 1432 MHz
- Section 95.1111(a) of the FCC's rules states, "Prior to operation, authorized health care providers who desire to use wireless medical telemetry devices must register all devices with a designated frequency coordinator."

# WMTS Update

- ASHE is the FCC's designated frequency coordinator:
- Two step process to register:
  - 1. Register the Facility
  - 2. Register the Telemetry Equipment







http://www.ashe.org/wmts/index.shtml

# ICC Code Development 2021 Cycle Group A Update

# ICC Code Development Cycle Status

- 2018 2019 Cycle "underway"
- 2018 Group A
  - IBC- E, IBC FS, IBC -G, IFC, IFGC, IMC, IPC, IPMC, IPSDC, IRC M, IRC- P, ISPSC, IWUIC, IZC
- 2019 Group B
  - Admin, IBC-S, IEBC, IECC-C, IECC-R/IRC-E, IgCC (Ch. 1), IRC B
- Group A ICC Committee on Healthcare
  - Alignment with current K-Tags



_			<u> </u>	
K-tag	Work Group	Proposal #	Section Modified	Proposal Summary
22	G/MOE	E052	IBC 1010.1.9.4	Manual locking provision - Staff Keys
21		E055	IBC 1010.1.9.7	Controlled egress doors - smoke detectors
21			IBC 1010.1.9.7	Controlled egress doors -cognitive
22		E059	IBC 1010.1.9.8.1	Delayed egress locking system exceptions
	MEP	E092	IBC 1020.5	Transfer air for both positive and negative pressure rooms
	G/MOE	E123	IBC 1107.5, 1107.5.1, 1107.5.1.1, 1107.5.1.2 (New)	Accessible units in Group I-1, Condition 1 & 2 Exceptions - not more than 50% water closets and roll in showers required to comply with ICC A117.1
	G/MOE		IBC 1107.5.2, 1107.5.2.1, 1107.5.2.2	Accessible units in Group I-2 Nursing homes Exceptions - not more than 90% water closets and roll in showers required to comply with ICC A117.1
	G/MOE	E125	IBC 1107.5.4	Accessible units in Group I-2 Rehab Facs Exceptions - not more than 50% water closets and roll in showers required to comply with ICC A117.1
	G/MOE			Assisted toileting and bathing - equivalent facilitation to the accessible toilet requirement in ICC A117.1 and the 2010 ADA Standard
		E129	IBC 1109.2, 1109.2.3 (New), 1109.2.3.1 (New), 1109.2.3.2 (New), 1109.2.3.3 (New), 1109.2.3.3.1 (New), 1109.2.3.3.2 (New), 1109.2.3.4 (New), 1109.2.3.5 (New), 1109.2.3.6 (New), 1109.2.3.7 (New), 1109.2.3.8 (New), 1109.2.3.9 (New)	Assisted toileting and bathing - removal of the requirement for permanently installed folding or fixed seats
41	F/FS	F012	IFC 310.2, 310.2.1, 310.3, 310.6	Patient smoking based on clinical need
933	F/FS	F033	IFC 403.8.2.4	Fire loss prevention in Operating Rooms
13	MEP	F069	IFC 604.1.1	Electrical systems and equipment must be maintained and tested per requirements listed in NFPA 99

G/MOE

G046

IBC 407.6.1

_					
K-tag	Work Group	Proposal #	Section Modified	Proposal Summary	
K524	MEP	F122 - P1	IFC 903.3.2	QR heads in smoke compartment with gas/decorative fireplaces	
K524	MEP	F122 - P2	IFGC 303.3.1	Exclusion of gas fireplaces in patient sleeping rooms	
K711,					
•	F/FS	F147	IFC 907.5.2.1, 907.5.2.3	Exception for both visible and audible alarms in hospitals	
<b>K</b> 211			·	Removal of wheeled equipment	
			IFC 1105.5.4.2.2, 1105.5.4.2.4,		
K363	F/FS	F188	1105.5.4.2.5	Corridor door clearances, hold opens and protective plates	
K241	G/MOE	F189	IFC 1105.6.1	MOE without return to compartment	
<b>K</b> 918	MEP	F192	IFC 1203.4.1, 1203.5.1	Inspection and testing requirements of emergency and standby power systems per NFPA 99	
K322	F/FS	F271	IFC CHAPTER 38	Align hospital labs with academic research labs	
	F/FS		IFC TABLE 5003.1.1(1), 5003.8.3, 5003.8.3.1, 5003.8.3.2, 5306.2; IBC: [F]T ABLE 307.1(1), [F] 414.2, [F]414.2.1, [F]414.2.2, [F]427.2	High-rise requirements for storage of gases in high-rise I-2 occupancies	
K925	F/FS	F286	IFC 5003.7.4	Restriction of sources of ignition in RT Areas	
K926	MEP	F295	IFC 5306.1.1	Training requirements of medical gas systems and associated equipment and cylinders	
K364	F/FS	FS039	IBC 710.5, 710.5.3	Pass thru opening requirements	
	F/FS	FS067	IBC 717.5.2	More accurately reflect typical installations of fully ducted systems	
K324	MEP	G040		separate the requirements for domestic cooking appliances and exhaust from the allowance for that area to be open to the corridor in a nursing home	
K324	MEP	G041	IBC 407.2.6	Exceptions for domestic cooking	
K362	F/FS	G042	IBC 407.3.1.1, 710.5.2.1	Non-rated doors in corridors requirements	
K256, K257			-	Exit access options from a suite	
<b>/</b> 255		IC044		Demoval of distance of traval expension	

Automatic release of hold opens

F/FS

F031

Table 405.2

	<u> </u>		<u> </u>	
tag	Work Group	Proposal #	Section Modified	Proposal Summary
24	MEP	G055	IBC 420.8, 420.8.1, 420.9 (New); IFC: 904.13	Separate the requirements for domestic cooking appliances and exhaust from the allowance for that area to be open to the corridor in an assisted living facility.
24	MEP	G056	IBC 420.8	Exceptions applicable to cooktops and ranges.
24	MEP	G058	IBC 422.1, 422.7	Domestic cooking training facilities Ambulatory Care
	G/MOE	G087	IBC 508.3.1.2	Use of non-separated mixed uses in hospitals
63		G112	IBC 603.1.1.1.1	Fire retardant-treated wood in shaft enclosures
62	G/MOE	G113	IBC 603.1.1.1.3.2	Fire retardant-treated wood in roof construction
21		M031	IMC 407.1	HVAC for I-2 and Ambulatory Care meet 170 & 99
24	MEP	M050	IMC 505.3.1	Allow recirculating hoods in I-1 & I-2
24	MEP	M051	IMC 505.3, 505.7	Address circular reference and coordinate with IBC & IFC changes
23	MEP	M081	IMC 920.1, 920.2, 920.3, 920.4	Suspended heaters not allowed in MOE
	MEP	P100	IPC 608.2	2 Water service pipes
'11, '12	F/FS	F024	IFC 403.4, 403.4.1, 403.4.1.1, 403.1.1.1, 403.4.1.2, 403.8, 403.8.1, 403.8.2, 403.8.3, 403.10, 403.10.3	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Ambulatory Care facilities - moves specific ambulatory care facility criteria so that it is a subset of Group B
11, 12	F/FS	F025		Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Ambulatory Care facilities - consistent use of care recipient instead of patient
'11, '12	F/FS	F026	IFC 403.3.2, 403.8.1.1.2, 403.8.2.2, 403.8.3.1, 403.10.3.3.1	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Ambulatory Care facilities - "location of special locking arrangements".
'11, '12	F/FS	F027	IFC 403.3.3, 403.8.1.2, 403.8.2.3, 403.8.3.1, 403.8.3.2, 403.8.3.3, 403.10.3.2	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Ambulatory Care facilities - consistent use of staff vs employee
'11, '12	F/FS	F028	IFC 403.3.4, 403.8.1.6, 403.8.2.3, 403.10.3.6, 405.1, 405.2	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Ambulatory Care facilities - clarification of drill requirements
'11, '12	F/FS	F030	IFC 403.8.1.3, 403.10.3.3	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Ambulatory Care facilities - resident training clarification
'11,			IFC 403.8.1.4, 403.10.3.4, 405.2,	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Ambulatory Care

facilities - consistent use of staff vs employee

K-tag	Work Group	Proposal #	Section Modified	Proposal Summary
				Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care
K711,			403.8.2.3, 403.10.3.5, 405.2, Table	facilities - allow for the timing of fire drills to not be "unexpected time and under varying
	F/FS	F032	405.2, 405.4, 405.8	conditions"
K711,				Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care
K712	F/FS	F039	405, 405.1	facilities - coordination of lock down plans
K920	F/FS	F073	IFC 604.4.1.1	RPT requirements
K346,				
K354	F/FS	F101	IFC 901.7	AASS out of service per NFPA 25/72 Exception
K909,				
K924,				Clarifies that the application of NFPA 99 includes the use, testing and labeling of medical gas systems
	MEP	F297 - P1	IFC 5306.5	and equipment
K909,				
K924,				Clarifies that the application of NFPA 99 includes the use, testing and labeling of medical gas systems
K928	MEP	F297 - P2	IPC 1202.1	and equipment
K372	F/FS	FS038	IBC 709.4.1	Smoke compartment definition and clarification of boundaries
K331	F/FS	FS086	IBC 806.9	Lockers considered interior finish
K224	G/MOE	E045	IBC 1010.1.3.2	Manual horizontal sliding doors
K222	G/MOE	E061	IBC 1010.1.9.9	Emergency lighting egress side of door

Group A Code Action Committee Hearings

15 April – 23 April Greater Columbus Convention Center: Columbus, OH



- Committee on Healthcare (CHC)
  - Submitted a total of 60 Proposals
  - Reviewing an additional 100+ Proposals
    - Planning to support additional 21 Proposals
      - 120° maximum temperature for handwashing
      - Requirement for tracer on water mains
    - Planning to oppose 26 Proposals
      - Deletion of fire damper exception in fire barriers in fully sprinklered building
      - Requirement for leak detection devices on water mains
      - Requirement for occupied indicator for toilet and bathing room doors
    - Monitoring remaining proposals



# ASHRAE Public Review Opportunities

#### ASHRAE and Continuous Maintenance Documents

- ASHRAE Standards on Continuous Maintenance
  - ASHRAE 170, ASHRAE 188, ASHRAE 89.3, etc.
- Allows changes on continuous basis
- Issued as Addendum
- Standards published about every 3 years
  - Include published addendum as part of republished standard

#### **ASHRAE 170 - 2017**

- Issued 14 Nov 2017
- Includes editorial reorganization
  - Hospital Spaces
  - Outpatient Spaces
  - Nursing Home Spaces
- Incorporates 12 published addenda to the 2013 edition:

#### STANDARD

#### ANSI/ASHRAE/ASHE Standard 170-2017

(Supersedes ANSI/ASHRAE/ASHE Standard 170-2013) Includes ANSI/ASHRAE/ASHE addenda listed in Appendix C

#### Ventilation of Health Care Facilities

See Appendix C for approval dates by the ASHRAE Standards Committee, the ASHRAE Board of Directors, the ASHE Board of Directors, and the American National Standards Institute.

This Standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standard Committee has established ad coursented program for regular publication of addendar or revisions, including procedures for timely, documented, comensus action on requests for change to any part of the Standard. The change submittal form instructions, and deadlines may be obtained in electronic from from the StellhRE-Westeller (wowasheave.org) or in paper form from the Senior Manager of Standards. The listest edition of an ASHRAE Standard may be purchased from the ASHRAE with the committee of the

© 2017 ASHRAE ISSN 1041-2336








#### **ASHRAE 170 - 2017**

- RTU Gas Vents
- Adiabatic humidifiers
- New exam room type
  - General and Special
- Prohibits controls to switch pressurization
- Reduces requirements for ECT Rooms
- Reduces requirements for Labs
- Increases requirements for Higher Hazard Exhaust
- Coordinates temperature requirements for SPD
- Clarifies Primary Diffuser Array definition
- Updates references



# **Public Input Process**

- Proposals submitted to Standard Committee
- Reviewed and processed/approved by committee
  - Can be approved, modified, returned, etc.
- Posted for public comment
  - https://osr.ashrae.org/default.aspx
  - ASHE announces postings of pertinent proposals
- Need Member INPUT!

# **Upcoming Addenda**

# Important Upcoming 170 Addenda

- Addendum q (30-day review March 23, 2018 to April 22, 2018)
  - The following changes are being proposed: Add "resident" to differentiate from "patient" in residential health applications (Section 2.1). Clarify that Standard 170 addresses more than outside air quantities, to better differentiate from Standard 62.1 (Section 2.6). Clarify that 170 does not establish "comprehensive thermal comfort design requirements". Those requirements are addressed in Standard 55 (Section 2.7). The text of the Standard will be coordinated with this revised scope in a future addendum, once the revised scope is approved.
- Addendum o (45-day review March 23, 2018 to May 7, 2018)
  - Alternative option for a voluntary risk-based approach to establish operational ventilation rates for spaces required in 170
- Addendum p (45-day review March 23, 2018 to May 7, 2018)
  - Updates to Table 7.1. as follows: delete the requirements for Residential Health, Care, and Support spaces, which are being relocated to a new Table 9.1 in Addendum n. Relocate and update filtration requirements. Part of that effort revised the Filter Bank No. 1 entries to be "MERV 8" from the prior entry of "MERV 7". Include requirements for unoccupied turndown of the spaces. Revise the space name terminology, table organization, and subheadings to better correlate with the 2014 FGI Guidelines for Design and Construction of Hospitals and Outpatient Facilities.



- Region 1 New York
- Genesee Valley Regional Association for Healthcare Engineers (GVRAHE) – Jim Gross
  - NYSDOH legionella regulations






- Region 3
- North Carolina Healthcare Engineers Association (NCHEA) – Terry Fair
  - North Carolina adoption of current version of FGI
    - Hospital but not Ambulatory Health





- Region 4
- Florida Healthcare Engineering Association (FHEA)
   Fred Kiesel
  - Science Screen Report





Providing the Nation's Schools with Free STEM Resources for the Classroom Since 1970



- Opportunity for Chapters to engage locally
- Succession
   Planning Strategic

   Imperative



# Benefits of Sponsorship



- BRANDING: Each episode is branded with your company logo in a PBS-style opening and closing message.
  We will also divert traffic to social media platforms you support.
- > EXCLUSIVITY: Each sponsorship territory is exclusive to your organization. Your channel is password-protected & monitored.
- PUBLIC RELATIONS: Working in cooperation with your corporate communications team, we will provide press release templates as well as testimonials from educators in your supported territory to announce your participation to local, regional and national media, employees, customers and state and local policy makers.
- > LONGEVITY: Unlike one-time donations or events that are often forgotten, a SCIENCE SCREEN REPORT OnLINE News Channel will be used continually in science classes as well as at home and on the go for many years to come, resulting in your branding message being seen by countless students and teachers in your sponsored communities. With your continued support, schools will build a valuable on-line video library of dynamic and up-to-date STEM content that will continue to grow year after year.
- > AUDIENCE: We are seen by more than 25,000,000 students in tens of thousands of schools each year.
- SURVEYS & USEAGE REPORTS: Surveys and teacher testimonials documenting the active use of SCIENCE SCREEN REPORT OnLINE in the classroom are provided for your records at the close of each school year.
- 501(c)(3) DOCUMENTATION: SCIENCE-SCREEN/REPORT/OnLINE cambe: provided lass attax deductible:501(c)(3) chiaritable: contribution through the Accreditation Board for Engineering & Technology (ABET)) and the National Museum of Education (NMOE).



**STEM FACT:** Mechanical engineering is the #1 major chosen by students who want to pursue a career in STEM.













# To support STEM education, please contact:

Scott J. Forman **Executive Director** 

908-879-0390 2scott@ssrvideo.com

Rachel Rorick Manager, Corporate Relations 973-252-1789

rachel@ssrvideo.com

Karen Cleirbaut **Director of Administrative Services** 908-879-0428

karenc@ssrvideo.com











- Region 5 Michigan
- Michigan Society for Healthcare Engineering (MiSHE)
   Pier-George Zanoni
  - MiSHE board members participating in stakeholders meetings to review and comment on State of Michigan proposed revisions to the healthcare licensing rules. Estimated final rule approval in 2019.
  - MiSHE has been reaching out to Michigan Department of Environmental Quality staff re input into the upcoming clarifications of state enforcement of the Federal Clean Drinking Water Act as it pertains to health care facilities with on-site water treatment systems that inject disinfectant chemicals to reduce Legionella bacteria in the water supply. Rules will include requirements for certified operators.



- Region 8 Missouri
- Missouri Society for Healthcare Engineering(MoSHE)
   Greg Hrbacek
  - MOSHE Advocacy continues to monitor the adoption of our new State Construction Standard.
  - MDHSS has submitted an emergency rule request for the formal adoption of the 2010/2014 FGI Guidelines and 2012 NFPA 101, Life Safety Code.



- Region 9 Arizona
- Arizona Chapter of the American Society for Healthcare Engineering (AzASHE) – Jacob Linhart
  - NFPA 99, 2012 Edition Risk Assessment (Section 4.2\*)
  - ASHRAE 188 (Water Management Program)
  - Ligature risk
  - Delayed Egress (Code interpretation)
  - Hospital Incident Command System understanding and overview

# Reminder - AL Recordings and Future 2018 Webinars

# AL Recordings/pptx Posting

- Developed an AL Webinar Page
  - <a href="http://www.ashe.org/advocacy/member/liaison-webinars.shtml">http://www.ashe.org/advocacy/member/liaison-webinars.shtml</a>
  - Will maintain last 4 webinars
  - Page requires member login



### AL 2018 Webinar Dates

- Q2 Wednesday 20 June
- Q3 Wednesday 19 September
- Q4 Wednesday 5 December
- All webinars will begin at 12:00 Noon CT



# Thank you for all you do to help optimize the health care physical environment!

© 2018 American Society for Healthcare Engineering, a personal membership group of the American Hospital Association 155 N. Wacker Drive, Suite 400 | Chicago, IL 60606 ashe.org | ashe@aha.org | 312-422-3800

