

Hospital
Top Ten State Life Safety Deficiency Citations
Statewide

March 27, 2019

Year Date Range: January 1, 2018 through December 31, 2018

Rank	Tag	Count	Description
1	K0353	36	Sprinkler System - Maintenance And Testing (NFPA 101)
2	K0345	26	Fire Alarm System - Testing And Maintenance (NFPA 101)
3	K0918	24	Electrical Systems - Essential Electric System (NFPA 99)
4	K0324	24	Cooking Facilities (NFPA 101)
5	K1011	23	Fire Doors (NFPA 101)
6	K0923	22	Gas Equipment - Cylinder And Container Storage (NFPA 99)
7	K1053	20	Emergency Management Plan (F.A.C. 59A-3.078)
8	K0914	20	Electrical Systems - Maintenance And Testing (NFPA 99)
9	K0920	19	Electrical Equipment - Power Cords And Extensions (NFPA 99)
10	K0363	16	Corridor - Doors (NFPA 101)

Note: The entire description of each deficiency can be found at http://ahca.myflorida.com/MCHQ/Current_Regs.shtml