



ਵੱਲ,

Principal,  
Delhi World Public School,  
Ghal Kalan, Moga.

ਨੰਬਰ 126 ਮਿਤੀ 06/06/2023

ਵਿਸ਼ਾ :- ਇਮਾਰਤ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਬਾਬਤ ਸਾਲ 2023-2025

ਹਵਾਲਾ :- ਆਪ ਦਾ ਪੱਤਰ ਨੰ: DPS/23/20 ਮਿਤੀ 20-05-2023

ਉਪਰੋਕਤ ਬਿਲਡਿੰਗ ਦਾ ਨਿਰੀਖਣ ਸਬੰਧਤ ਜੇ.ਈ. ਵੱਲੋਂ ਕੀਤਾ ਗਿਆ ਅਤੇ ਇਹ ਬਿਲਡਿੰਗ ਸਾਲ 2023-24 ਲਈ ਸੁਰੱਖਿਅਤ ਪਾਈ ਗਈ ਹੈ। ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਆਪ ਨੂੰ ਮਿਤੀ 31-03-2024 ਤੱਕ ਦਾ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਹੈ। ਅੱਗੇ ਤੋਂ ਹੇਠ ਲਿਖੀਆਂ ਹਦਾਇਤਾਂ ਵੱਲ ਵਿਸ਼ੇਸ਼ ਧਿਆਨ ਦਿੱਤਾ ਜਾਵੇ :-

- 1 ਬਿਲਡਿੰਗ ਦੇ ਆਲੇ ਦੁਆਲੇ ਅਤੇ ਛੱਤਾਂ ਉਪਰ ਪਾਣੀ ਨਾ ਖਤਾ ਹੋਣ ਦਿੱਤਾ ਜਾਵੇ।
- 2 ਜੇਕਰ ਇਮਾਰਤ ਵਿਚ ਕਿਸੇ ਕਿਸਮ ਦੀ ਤਰੇੜ ਆ ਜਾਂਦੀ ਹੈ ਤਾਂ ਉਸ ਜਗ੍ਹਾ ਨੂੰ ਤੁਰੰਤ ਖਾਲੀ ਕੀਤਾ ਜਾਵੇ ਅਤੇ ਉਸ ਦੀ ਰਿਪੋਅਰ ਕਰਵਾਈ ਜਾਵੇ।
- 3 ਕਿਸੇ ਕਿਸਮ ਦੀ ਉਸਾਰੀ ਵਿਚ ਵਰਤੇ ਗਏ ਮਟੀਰੀਅਲ ਦੀ ਜੁਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ, ਆਪ ਵੱਲੋਂ ਨੱਥੀ ਕੀਤੇ ਨਕਸ਼ੇ ਤੋਂ ਇਲਾਵਾ ਜੇਕਰ ਆਪ ਵੱਲੋਂ ਵਾਧੂ ਉਸਾਰੀ ਕਰਨੀ ਹੋਵੇ ਤਾਂ ਉਸਦੀ ਮੰਨਜ਼ੂਰੀ ਇਸ ਮਹਿਕਮੇ ਤੋਂ ਲਈ ਜਾਵੇ।
- 4 ਡਾਇਰੈਕਟਰ ਜਰਨਲ ਸਕੂਲ ਸਿੱਖਿਆ ਵਿਭਾਗ ਪੰਜਾਬ ਸਟੇਟ ਪ੍ਰੋਜੈਕਟ ਸਰਵ ਸਿੱਖਿਆ ਅਭਿਆਨ ਦੇ ਪੱਤਰ ਨੰ: 75444 ਮਿਤੀ 06-11-2009 ਮੁਤਾਬਿਕ ਸਕੂਲ ਵਿਚ ਅੱਗ ਬੁਝਾਉਣ ਵਾਲੇ ਯੰਤਰ ਚਾਲੂ ਹਾਲਤ ਵਿਚ ਰੱਖੇ ਜਾਣ ਕਿਸੇ ਵੀ ਅਣਸੁਖਾਂਫ਼ੀ ਦੁਰਘਟਨਾ ਦੀ ਸਾਰੀ ਜਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ
- 5 ਅਗਲੇ ਸਾਲ 2024-25 ਦੀ ਇੰਸਪੈਕਸ਼ਨ ਕਰਾਉਣੀ ਯਕੀਨੀ ਬਣਾਈ ਜਾਵੇ।

ਨੱਥੀ/ਸਰਟੀਫਿਕੇਟ।

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,  
ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ ਭ ਤੇ ਮ ਸਾਖਾ,  
ਮੋਗਾ।

PROFORMA FOR SAFETY OF SCHOOL BUILDING

PART-I

(To be filled by the Head of School / Institute )

- 1) Name of the School . DELHI WORLD PUBLIC SCHOOL
- 2) Location . GHAL KALAN(MOGA) NEAR P.S Sadar G.T Road MOGA
- 3) Plot Area. 100072 Sq ft
- 4) Plinth Area.  $8949 + 15690 + 725 = 25364$  Sq feet = 2152 Sq.mtr
- 5) Number of storey's 1
- 6) Year of construction of Building 2007
- 7) If the building has been constructed under the Supervision of the qualified Engineer, the following details may be given:-
  - a) Name of the Engineer with Qualification.
  - b) Address of Engineer.
  - c) Set of structural drawing used in the construction . Available.
  - d) Name & address of Architect with qualification :
- 8) Whether the building has been constructed for the Purpose school .  
Residential purpose and converted for use as a school .  
DIRYA Bansal  
DIRYA Bansal  
Yes / No  
Yes / No
- 9) Material used for Roof .
  - a) R.C.C slab R.B.C Slabs
  - b) R.S. Joist & Battens
  - c) Wooden Joist & BattensYes / No  
Yes / No  
Yes / No
- 10) Material used for walls .
  - a) Mud Mortar.
  - b) Cement Mortar
  - c) Lime Mortar.Yes / No  
Yes / No  
Yes / No
- 11) Flooring .
  - a) Conglomerate
  - b) Terrazzo.
  - c) Brick PavingYes / No  
Yes / No  
Yes / No
- 12) A detailed drawing indicating dimension of Room Alongwith size and location of doors and windows (attached).
- 13) For Fire Safety .
  - a) Weather the width of the staircase is 1.5 Mtr .
  - b) Weather portable fire exiting .
  - c) Weather School building is free from inflammable & toxic material
  - d) Weather Cooking of food is done at a safe place
  - e) Weather any thatch of combustibile material as been Used.Yes / No  
Yes / No  
Yes / No  
Yes / No  
Yes / No


- 14) Requirement for fire Protection Arrangements under NBC  
Part -IV  
(For Building height Less than 15metre)
- |   |   |          |
|---|---|----------|
| a) Weather house Real provided.   | : | Yes / No |
| b) Weather down corner provided.  | : | Yes / No |
| c) Weather automatic sprinkler provided.  | : | Yes / No |
| d) Weather underground static water storage tank of Capacity 50,000Ltr.(It converted are excess 1600sqm)  | : | Yes / No |
| e) Weather over head tank of capacity 10,000 Ltr. Exists.(in case of house real) 20,000 Ltr.  | : | Yes/ No  |
| f) Weather one electric and one diesel pump of 3 kg/ cum Pressure of capacity 1620 LPM.One electric pump of Capacity 180LPM exist near underground static tank. | : | Yes/No   |
| g) Weather a pump 3 Kg /cum preasur & 450/500 LPM Exist near over head tank.  | : | Yes / No |

School stamp

PART -II

(To be filled by the S.D.E for PWD (B&R) Department )

- a) I have visited the above mentioned school on date 06-June-2023 And have been visually inspected it from all angles of safety and fined it fit for normal used as school buildings.
- b) In case and addition / alteration of expansion and modifications to this building is to be carried out the same be carried out unde
- c) r the supervision of a qualification Engineer and this certificate may be re-obtained after the completion from the undersigned.
- d) In case the building is affected by food , or if there is settlement of walls/ foundation of sagging of roofs etc. immediate inspection of the undersigned by arranged to check the stability and safety of the building.
- e) This building can be safety occupied for normal used upto (indicate upto which it can be used ) 31-03-2024 - (one year only)

  
Sub Divisional Engineer  
Provincial Sub Division.  
PWD (B&R) Dc Moga.